



SYSTEMS DIVISION

PARKER HANNIFIN, 18321 JAMBOREE BOULEVARD • IRVINE, CALIFORNIA 92664

WASG-11750

verbidden
van DORT 11/10/72
W/5-22-73

NUMBER: EER5716068

TITLE: Development Report,
Mass Flow Controller
PN 5716068

(NASA-CR-128639) DEVELOPMENT REPORT, MASS
FLOW CONTROLLER PN 5716068 W. Taylor
(Parker-Hannifin Corp., Irvine, Calif.)
12 Apr. 1972 139 p A/22 GSCI 211

N73-12860

Unclassified

RECD JUL 3 1972
L.T.S.

REFERENCE: Project 156

REPRODUCED BY
U.S. DEPARTMENT OF COMMERCE
NATIONAL TECHNICAL
INFORMATION SERVICE
SPRINGFIELD, VA 22161

PREPARED BY:

W. Taylor
Project Engineer

APPROVED BY:

D. Bora
Principal Engineer

NO.	EER 716068		BY	WT	PAGE	i
REV LTR	A					
DATE	4-12-72					

LIST OF EFFECTIVE PAGES

This document consists of 135 pages as follows:

<u>Page</u>	<u>Rev. Ltr.</u>
Cover	NC
i	A
ii	NC
iii	NC
1 through 45	NC
46	A
47	NC
48	A
48A	A
49	A
50 through 56	NC
Appendix A through Appendix J	NC

CONTENTS

<u>Section</u>	<u>Page</u>
1.0 Summary	1
2.0 Introduction	2
3.0 Basic Design Concept	5
3.1 Tolerance	6
3.2 Bellows Charge	7
3.3 Thermal Response	9
4.0 Design	12
4.1 Housing	12
4.2 Shutoff Valve	12
4.3 Cylinder and Cage	12
4.4 Bellows Assembly	12
4.5 Belleville Spring	14
4.6 Solenoid Pilot Valve	14
5.0 Test Program	15
5.1 Component Testing	15
5.1.1 Cage and Cylinder Assembly	15
5.1.2 Prototype Bellows	16
5.2 Prototype MFC Testing	16
5.3 PreProduction Testing	17
5.4 Acceptance Tests	19
5.4.1 Leakage	20
5.4.2 Pressure Response	20
5.4.3 Control Pressure with Varying Inlet Pressure	22
5.4.4 Control Pressure with Varying Temperature	22
5.4.5 Thermal Response	22
5.5 Design Verification Testing	22
5.5.1 Endurance Test	22
5.5.2 Pressure Drop Test	23
5.6 Helium Test	23
6.0 Conclusions and Recommendations	24

Figures

1 thru 29

25 thru 53

Tables

1 thru 3

54 thru 56

NO.	EER5716068		BY	WT	PAGE	iii
REV LTR	NC					
DATE	1-19-72					

CONTENTS (continued)

<u>APPENDICES</u>	<u>Page</u>
A	A-1 thru A-26
B	B-1 thru B-5
C	C-1 thru C-5
D	PTS5716187
E	PTS5716068
F	F-1 thru F-12
G	G-1 thru G-4
H	DVT5716068
J	J-1 thru J-3

NO.	EER5716068		BY	WT	PAGE	1
REV LTR	NC					
DATE	1-19-72					

1.0

SUMMARY

This is the final report of the work performed under contract to NASA Manned Space Flight Center on the design and test of an all mechanical Mass Flow Controller. The program involved design, development, manufacture of four MFC units and a test program using inert gas as the test medium. The unit controlled the pressure within ± 1 percent. An analytical method is described for relating the control pressure error with error in mass flow.

NO.	EER5716068		BY	WT	PAGE
REV LTR	NC				
DATE	1-19-72				

2.0 INTRODUCTION

Control of the mass flow rate is essential for controlling the fuel-oxidizer mixture ratio or controlling the thrust level of a rocket engine. In a rocket engine designed for a constant thrust level, the flow rate of the propellants must be maintained essentially constant. When gaseous propellants are used, it becomes more difficult to maintain a constant flow rate than when liquid propellants are used. In a typical rocket engine system using gaseous propellants, both the pressure and temperature of the propellant supply will vary. The function of a mass flow controller is to compensate for these variations as required to maintain the flow rate constant.

An all mechanical approach to mass flow control is illustrated in Figure 1. In this approach a fixed flow restriction is combined with a temperature biased absolute pressure regulator. The pressure regulator maintains a constant control pressure, P_o , so long as the temperature of the propellant does not change, even though the propellant inlet pressure varies. Under these conditions the pressure at both ends of the fixed flow restriction is constant and the flow rate is therefore constant. When the propellant temperature changes, the temperature biased pressure regulator alters the control pressure proportionally so as to maintain the flow rate constant through the fixed restriction.

The equation for subsonic gas flow through a fixed restriction can be approximated by the equation

$$\omega = \frac{2g}{R} CA \sqrt{\frac{P_c (P_o - P_c)}{ZT}} \dots \dots \dots \quad (1)$$

It can be seen that the flow rate through the fixed restriction will be constant if the term under the radical is maintained constant. This term is constant when the pressure drop, $P_o - P_c$, is caused to vary with the absolute temperature, T . This is easily seen when P_c and Z are constant; actually these two terms vary somewhat with temperature, which requires minor modification to the proportionality maintained between $P_o - P_c$ and T .

NO.	EER5716068	BY	WT	PAGE	3
REV LTR	NC				
DATE	1-19-72				

DEFINITIONS OF SYMBOLS

A	Flow area of throttling element, in ²
A _b	Bellows area, in ²
C	Coefficient of discharge, dimensionless
C _b	Specific heat of bellows, $\frac{\text{BTU}}{\text{LB} - {}^\circ\text{R}}$
F	Force, lbs
g	Conversion Factor, $\frac{\text{LBm ft}}{\text{LB}_f - \text{sec}^2}$
h	Film Coefficient, $\frac{\text{BTU}}{\text{sec} - \text{in}^2 - {}^\circ\text{R}}$
I _{sp}	Specific Impulse, $\frac{\text{LB f}}{\text{LB}_m - \text{sec}}$
K _b	Thermal Conductivity of Bellows $\frac{\text{BTU}}{\text{sec} - \text{in} - {}^\circ\text{R}}$
K _s	Thermal Conductivity of Belleville Spring, $\frac{\text{BTU}}{\text{sec} - \text{in} - {}^\circ\text{R}}$
L	Bellows Stroke, in
L _b	Bellows Conduction Path, in
L _s	Belleville Spring Conduction Path, in
M _b	Mass of Bellows Corrugations, lb
M _s	Mass of Belleville Spring, lb
P _b	Bellows Charge Pressure, psia
P _c	Thrust Chamber Pressure, psia
P _i	Inlet Pressure, psia
P _o	Control Pressure, psia
R	Specific Gas Constant $\frac{\text{Ft- LB}_f}{\text{LB}_m - {}^\circ\text{R}}$
T _b	Temperature of Bellows, {}^\circ R
T _{bo}	Temperature of Bellows, {}^\circ R
T _g	Temperature of Propellant, {}^\circ R
T _s	Temperature of Belleville Spring, {}^\circ R

NO.	EER5716068		WT	PAGE	4
REV LTR	NC				
DATE	1-19-72				

DEFINITIONS OF SYMBOLS (continued)

- T Temperature, ° R
t Time, secs
V Volume, in³
w Flow Rate, lb/sec
x Percent error in oxygen flow rate
y Percent error in hydrogen flow rate
Z Compressibility Factor, dimensionless

NO.	EER5716068	BY	WT	PAGE	5
REV LTR	NC				
DATE	1-19-72				

3.0

BASIC DESIGN CONCEPT

In the all mechanical approach a fixed flow restriction is combined with a temperature biased absolute pressure regulator, hereinafter referred to as the Mass Flow Controller (MFC). In a rocket engine the injector together with the ducting connecting the injector and the MFC constitute the fixed flow restriction. At the beginning of the program this flow restriction was assumed to result in a 60 psi pressure drop when passing rated flow at 100°F to a combustion chamber at 300 psia. The chamber pressure varies somewhat with the temperature of the entering propellant in accordance with Figure 2.

Figure 2 was obtained from the expression

$$\frac{P_c(T)}{P_c(560)} = \frac{I_{sp}(T)}{I_{sp}(560)} \dots \dots \dots \dots \quad (2)$$

which is valid for constant mass flow of the rocket engine.

The variation of specific impulse with temperature was obtained from Figure 3. Figure 3 was prepared from data from NASA Houston for a rocket engine with a O/F ratio of 4, expansion ratio of 40 and a thrust chamber pressure of 300 psia. This curve is valid for O/F ratio from 3.8 to 4.2.

Figure 4 includes two curves, one for oxygen gas and one for hydrogen gas, showing the required variation in control pressure with temperature for constant mass flow. The curves were prepared using the equation

$$\omega = \frac{C A P f M}{Z T} \dots \dots \dots \dots \quad (3)$$

Which is a more exact equation than (1) for the flow through a fixed restriction.

Figure 5 is a schematic drawing of the Mass Flow Controller. It incorporates a shutoff poppet, which is controlled by a two-position, three-way solenoid pilot valve for the off-on function. Downstream of the shutoff poppet is the pressure balanced throttling element, consisting of a stationary cylinder and a rotating cage. The cage is normally positioned by the belleville spring so that its slots are aligned with the slots in the cylinder. When the pressure at the outlet, P_o , rises to the set value, the bellows, which connects with the cage through a linkage, rotates the cage toward a more restrictive position. The amount of cage rotation is that required to maintain the outlet pressure at its correct value for the temperature of the propellant. When the propellant temperature increases, the internal pressure in the bellows increases and causes the MFC to control the outlet pressure to a higher value.

NO.	EER5716068		BY	WT	PAGE	6
REV LTR	NC					
DATE	1-19-72					

In order for the MFC to vary the outlet pressure with temperature in accordance with one of the curves of Figure 4, the slope must be correct and the pressure level must be correct. The slope of the curve is determined primarily by the bellows charge pressure: the greater the charge pressure, the steeper the slope (larger pressure change for a given change in propellant temperature). The pressure level of the MFC is determined by the pressure charge and the belleville spring load.

3.1 Tolerance

The all mechanical MFC is basically a temperature biased absolute pressure regulator. It uses a helium charged bellows to sense both the pressure and the temperature of the flowing gas. Because the MFC is a pressure operated device its precision is best expressed in terms of a tolerance in the control pressure, e.g. ± 3 psi at 0°F temperature. It is of interest however to relate pressure tolerance to tolerance in mass flow, mixture ratio and thrust when two controllers (an oxygen MFC and a hydrogen MFC) are used to supply a rocket engine.

When one MFC delivers its propellant at a higher or lower pressure than the correct value, it causes a proportional error in the flow rate of its propellant. This error in flow rate results in a deviation in the chamber pressure of the rocket engine. The change in chamber pressure represents a change in the outlet pressure of the fixed flow restriction of the other propellant; consequently it causes an error in the mass flow rate of the other propellant even when the MFC for that propellant is controlling without a pressure error.

An analytical method was developed for relating these tolerances. It consists of assuming a percentage error in flow rate of each propellant and calculating the resulting mixture ratio, chamber pressure, and control pressure for each propellant. Figures 6 and 7 were constructed from the results of several such computations. Details of the method are described below.

An error of $+x\%$ error in oxygen flow rate and $+y\%$ error in hydrogen flow rate results in the following O/F mixture ratio

$$\text{O/F} = \frac{4(1 + \frac{x}{100})}{1 + \frac{y}{100}} \quad \dots \dots \dots \dots \dots \dots \dots \quad (4)$$

and a change in flow rate through the engine of

$$\frac{\Delta\omega}{\omega} = \frac{4 \frac{x}{100} + \frac{y}{100}}{5} \quad \dots \dots \dots \dots \dots \dots \dots \quad (5)$$

NO.	EER5716068		BY	WT	PAGE	7
REV LTR	NC					
DATE	1-19-72					

A new chamber pressure was calculated using the chamber pressure from Figure 2 and modifying it by the new mass flow

$$P_c = 1 + \frac{\Delta\omega}{\omega} \times P_c \text{ (from curve)}$$

Equation (1) was then used to calculate a new outlet pressure, P_o , for each propellant. These two pressures were used to establish a point on one curve of Figure 6 or Figure 7.

For an oxidizer-fuel ratio of four, the hardware required for an oxygen MFC should be the same size as a hydrogen MFC. This follows since for equal pressure drop the flow passages should be approximately the same for both propellants. It is therefore logical to expect equal pressure errors of the MFC for each propellant. Figures 6 and 7 show that for equal pressure errors the hydrogen MFC will suffer approximately twice the mass flow percentage error of the oxygen MFC.

Figure 8 is a plot of the allowable pressure band over the entire temperature range band on a mass flow error of 2-1/2 percent and 5 percent for the oxygen and hydrogen units respectively. This figure shows that the allowable pressure error decreases as the temperature of the propellants decreases.

The allowable pressure control band can be increased without increasing the mass flow error by designing the system for a greater pressure drop through the fixed flow restriction. (See paragraph 6.3)

3.2 Bellows Charge

The bellows is charged with helium gas and subsequently sealed. The charge required to cause the MFC to control the outlet pressure in accordance with Figure 3 may be calculated from a force balance. The force balance, in its simplest form, consists of the

1) spring force, F : belleville spring load plus the installed load in the bellows (the bellow is assembled so that it is in compression throughout its stroke). The spring force acts to hold the throttling element in its open position. This force is a function of temperature, decreasing approximately 2% per 100°F increase.

2) gas charge, P_b , acting over the effective areas of the bellows, A_b , pushes the throttling element toward the open position. This force varies directly with absolute temperature.

3) outlet pressure, P_o , acting over the effective area of the bellows, A_b , opposes the other two forces and balances them when the outlet pressure reaches the correct pressure value.

The force equation in its simplest form is

If the terms $\frac{F}{A_b}$ and P_b represent their magnitude at 100°F temperature, their magnitude at any lower temperature T

The above three equations and the values of P_o taken from Figure 3 can be used to calculate P_b and $\frac{F}{A_b}$. These calculations for the oxygen unit give

$$P_b = 112 \text{ psia at } 100^\circ\text{F}$$

$$\frac{F}{A_b} = 248 \text{ psi at } 100^\circ\text{F}$$

During testing of the prototype MFC it was discovered that the above force balance requires modification in order to account for a temperature dependent closing force. This force results from the pressure drop between the throttling element and the MFC outlet. The pressure drop creates a difference in pressure across the belleville spring, resulting in an additional closing force on the throttling device. Additionally, the pressure drop results in a greater pressure surrounding the bellows than is indicated by the outlet pressure. These two effects are temperature dependent since pressure drop, at constant flow, is temperature dependent.

The effect of the additional closing force was determined empirically. It results in the revised charge pressures and spring loads as follows:

NO.	EER5716068		BY	WT	PAGE	9
REV LTR	NC					
DATE	1-19-72					

For the oxygen MFC

$$P_b = 148.7 \text{ psia at } 100^\circ\text{F}$$

$$F/A_b = 246.3 \text{ psi}$$

For the hydrogen MFC

$$P_b = 133.6 \text{ psia at } 100^\circ\text{F}$$

$$F/A_b = 261.4 \text{ psi at } 100^\circ\text{F}$$

3.3 Thermal Response

The thermal response of the MFC is determined by the rate at which the belleville spring and the helium charge inside the bellows respond to a temperature change of the propellant gas. The most rapid change of propellant temperature occurs when the MFC, stabilized at its maximum temperature (100°F), is opened with a gas supply at its minimum temperature (-210°F for an oxygen MFC, -260°F for a hydrogen MFC). In this circumstance the MFC will regulate to a pressure higher than it should until the bellows and belleville cool to near the temperature of the propellant gas. Slower thermal response occurs when oxygen is the propellant as its thermal conductivity is less than that of hydrogen.

Bellows - The bellows thermal response was calculated by assuming that the mass of the bellows is concentrated in the center of the bellows wall and that the length of the conduction path is one-half the wall thickness. The heat transferred from the center of the wall to its outer surface is derived from cooling the bellows mass; i.e.

$$M_b C_b \frac{dT_b}{dt} = \frac{K_b A_b}{L_b} (T_b - T_{bo}) \dots \dots \dots \dots \dots \dots \quad (9)$$

where the expression on the left side of the equation is the cooling rate of the bellows and the expression on the right the rate of conduction to the outer wall of the bellows.

The energy conducted to the outer wall of the bellows is transferred to the propellant by convection.

$$\frac{K_b A_b}{L_b} (T_b - T_{bo}) = h A_b (T_{bo} - T_g) \dots \dots \dots \dots \dots \dots \quad (10)$$

Equation 10 can be solved for T_{bo} and the result substituted in equation 9. The resulting expression may be written

$$dt = \frac{\frac{1 + \frac{K_b}{hL_b}}{\frac{K_b A_b}{L_b M_b C_b}} - \frac{dT_b}{T_b - T_g}}{d T_b}$$

an expression which can be integrated if T_b and t are considered as the only variables. Actually, conductivity, specific heat, and the film coefficient vary with temperature, but not sufficiently to invalidate the result. Integration gives

$$t = \frac{1 + \frac{K_b}{h L_b}}{\frac{K_b A_b}{L_b M_b C_b}} \ln \frac{(T_b - T_g)t}{(T_b - T_g)t} = 0 \dots \dots \dots \dots \dots \dots \quad (11)$$

Figure 10 is a plot of T_b vs t obtained from equation 11 for the oxygen MFC. Values used for the constants are listed below.

$$K_b = 1.16 \times 10^{-4} \frac{\text{BTU}}{\text{Sec} \cdot \text{in} \cdot {}^\circ\text{F}}$$

$$L_b = 7.85 \times 10^{-3} \text{ in}$$

$$C_b = .076 \frac{\text{BTU}}{\text{lb} \cdot {}^\circ\text{F}}$$

$$A_b = 38.2 \text{ in}^2 \quad (\text{Bellows area and mass were calculated neglecting the end fittings})$$

$$M_b = .174 \text{ lbs}$$

$$h = .34 \times 10^{-3} \frac{\text{BTU}}{\text{Sec} \cdot \text{in}^2 \cdot {}^\circ\text{F}}$$

Belleville Spring - An analogous expression to equation 11 for the relationship between belleville spring temperature T_s and time t is as follows:

$$t = \frac{1 + \frac{K_s}{h L_s}}{\frac{K_s A_s}{L_s M_s C_s}} \ln \frac{(T_s - T_g)t}{(T_s - T_g)t} = 0 \quad (12)$$

NO.	EER5716068		BY	WT	PAGE	11
REV LTR	NC					
DATE	1-19-72					

The equation was derived in the same manner as the equation for the bellows. The spring was considered symmetrical to a plane passing through its center (perpendicular to its axis) with the length of heat transfer equal to 1/4 its thickness and a heat transfer area equal to its surface area, or

$$L_s \approx .0188$$

$$A_s = 18 \text{ in}^2$$

$$M_s = .196 \text{ in}^2$$

Film coefficient, conductivity and specific heat was assumed to be the same as for the bellows.

Figure 9 includes a plot of the belleville spring temperature vs. time obtained from Equation 12.

The temperature of the bellows and the belleville spring at any time t was used to calculate a regulated outlet pressure for that same time. The technique used was to calculate (1) the amount that the helium gas charge pressure decreases (assuming that the helium gas temperature closely follows the bellows wall temperature) as a result of its temperature decrease from its initial temperature to its temperature at time t and (2) the amount that the belleville spring force increases ΔF_s ; as a result of its temperature decrease from its initial temperature to its temperature at time t . The regulated pressure at time t was taken to be its initial regulated pressure (360 psia) plus the belleville spring effect ($\Delta F_s / A_B$) less the pressure change of the helium charge. (This calculation did not include a term for the pressure drop through the unit. It did use a bellows charge pressure, 112 psia at 100 degrees F, which is correct for a MFC without the pressure drop effect (See paragraph 3.2). Results of the calculation are plotted in Figure 10. It shows that the MFC, when subjected to a step temperature change of 310 degrees F, regulates within three psi of the correct pressure setting for the new propellant temperature within approximately two seconds. It is interesting to note from Figure 11 that after 2 seconds time the temperature of both the bellows (-162 degrees F) and the belleville spring (-67 degrees F) are considerably greater than the propellant temperature (-210 degrees F) and yet the regulation pressure is within 3 psi of the correct regulation pressure. This apparent paradox is explained by noting that the effect of a bellows temperature error is opposite from the effect of a belleville spring temperature error; i.e. a bellows temperature higher than the propellant causes a high regulation pressure whereas a high belleville spring temperature causes a low regulation pressure.

NO.	EER5716068		WT	PAGE	12
REV LTR	NC				
DATE	1-19-74				

4.0

DESIGN

The Mass Flow Controller design is shown in Figures 11 and 12. Its primary elements are a shutoff valve incorporating a housing, a shutoff valve, a pressure balanced throttling device, consisting of a stationary cylinder and a rotating cage, a hermetically sealed bellows assembly containing a helium gas charge, and a negative rate belleville spring. These elements are pictured in Drawing 5716187 and Drawing 5716068, reduced size copies of which are included as Figures 11 and 12. These elements are discussed in some detail below.

4.1

Housing

The MFC is designed for an operating pressure of 2000 psia inlet and 360 psia outlet (at 100 degrees F). Proof pressures are 3000 psia and 540 psia respectively. The housing is structurally sound for outlet pressures up to 2000 psig but such pressures would damage the bellows. Safety factors at the flanges for inlet and outlet pressures of 3000 and 2000 psig respectively are shown on Figure 13.

4.2

Shutoff Valve

The shutoff valve is a piston operated type controlled by a separate solenoid pilot valve. The poppet, which is clamped to the piston at its inner periphery, has some self-alignment capability at its seating surface, which projects beyond the skirt of the piston and seats on a raised, flat-lapped annulus on the cylinder. In the closed position the poppet is pressure loaded in contact with the seat.

The piston is normally spring loaded to the closed position. Pressure at the inlet communicates with the piston chamber via the solenoid pilot valve. When the solenoid pilot valve is energized, the piston chamber is connected to the outlet port of the MFC. This causes the piston chamber to bleed down until the inlet pressure opens the piston. The piston is prevented from slamming opening by the built-in snubber action as the piston approaches its open position stop.

The piston is guided by a CRESstem which moves in a filled Teflon bearing. Its peripheral seal consists of two step-cut piston rings of a filled Teflon material backed up by a CRES expander ring.

4.3

Cylinder and Cage

The throttling element consists of a stationary cylinder and a rotating cage, each with six peripheral slots. Throttling occurs as the slots in the cage rotate out of alignment with those in the cylinder.

NO.	EER5716068		BY	WT	PAGE	13
REV LTR	NC					
DATE	1-19-72					

4.3

(continued)

There are six slots in the cylinder and six matching slots in the cage. Four of the slots are 1/8-inch wide and two are 1/4-inch wide. The orientation is such that the four narrow slots close simultaneously when the two wide slots are in their mid position. There is .0025 radial clearance (nominal) between the two parts when installed. Twenty-three degrees rotation from the closed position is required to fully open all slots. The flow area versus rotation is shown on Figure 14.

4.4

Bellows Assembly

The bellows used in the MFC was an off-the-shelf item. It has 7-1/2 active convolutions and was obtained by machining an existing 14 convolution bellows obtained from Robertshaw Controls Company, Knoxville, Tennessee. This bellows, Robertshaw P/N A2000A08, is a single-ply, hydrostatically formed, seamless, 18-8 CRES bellows with the following specifications:

OD: 2.00

ID: 1.34 inches

Wall thickness: .0157 in.

Length per active corrugation: .110 in.

Spring rate per active corrugation: 4000 lb/in

Maximum stroke per action corrugation: .023 in.

Effective area: 2.22 in.²

Maximum pressure rating: 395 psi differential

Bellows Spring Rate

The spring rate of the bellows is made up of a mechanical portion, or that due to the spring rate of the 7-1/2 active convolutions, and a pneumatic portion. The pneumatic spring rate results from the fact that the bellows cannot be deflected without compressing or expanding the internal charge. If the internal charge follows an isothermal process during deflection, the pneumatic spring rate may be calculated as follows:

Differentiating the perfect gas equation for an isothermal process ($pV = \text{constant}$),

$$P_b \frac{dV}{dL} + V \frac{dP_b}{dL} = 0$$

$$\text{Since } dV = \frac{A_B}{B} dL \text{ and } dP = \frac{dF}{A_B}$$

$$\frac{dF}{dL} = - A_B \frac{P}{V^2} \quad (13)$$

NO.	EER5716068		BY	WT	PAGE	14
REV LTR	NC					
DATE	1-19-72					

The mechanical spring rate is approximately 535 lb/inch at room temperature and decreases with increasing temperature at a rate of approximately 2% (10.7 lbs/inch) per hundred degree change. The pneumatic rate is directly proportional to the internal pressure and consequently increases with increasing temperature. The bellows assemblies were charged with helium to 148.7 psia (bellows assembly at midstroke, 100 degree F temperature) for the oxygen MFC and 133.6 psia for the hydrogen MFC. (See Paragraph 3.2) The spring rate variation with temperature is shown below for the bellows used in the oxygen MFC.

Temperature <u>Degrees F</u>	Mechanical Spring Rate <u>lb/inch</u>	Pneumatic Spring Rate <u>lb/inch</u>	Assembly Spring Rate <u>lb/inch</u>
100	532	490	1022
-210	565	219	784

4.5 Belleville Spring

The spring loads, as described in the preceding paragraph, were found to be :

$$F = 246.3 \times 2.22 = 546 \text{ lbs. for the oxygen unit and}$$

$$F = 261.4 \times 2.22 = 580 \text{ lbs. for the hydrogen unit}$$

Approximately 20 lbs of each of the above loads is obtained from the compression of the bellows. The remainder is the calculated load of the belleville at its mid-stroke position.

The belleville spring operates in the negative spring rate regime throughout the operating stroke (.036 inches) of the linkage. The spring rate of the belleville spring was designed to be near the spring rate of the bellows assembly. If the two were equal (but of opposite sign) the net spring rate would be zero. A zero spring rate system would permit the throttling device to take whatever restrictive position required by changing pressure and/or temperature of the propellant without change of outlet pressure. For stability reasons, however, it is desirable that the net spring rate remain positive.

4.6 Solenoid Pilot Valve

The Solenoid Pilot Valve is a two-position, three-way direct operating valve purchased from Circle Seal Corporation, Part No. SV 30 A 32 P 4 T, cleaned for oxygen service.

NO.	EER5716068		BY	WT	PAGE	15
REV LTR	NC					
DATE	1-19-72					

5.0

TEST PROGRAM

The test program was originally planned to include component tests, prototype tests, Acceptance Tests and Design Verification Tests. It was necessary to expand this to include additional tests, termed "Pre Production Tests" because of unanticipated problems requiring (1) redesign of the cage and cylinder and (2) modifying the bellows charge.

5.1

Component Testing

At the beginning of the program, certain components were recognized as being critical to the success of the all-mechanical Mass Flow Controller. These were (1) the cage and cylinder assembly (2) the charged bellows and (3) the belleville spring. Development tests were planned for these components to verify their performance as components before assembly into a complete MFC.

5.1.1

Cage and Cylinder Assembly

A prototype case and cylinder were machined from 17-4 barstock in accordance with Parker Drawings 5716069 and 5716070, both to Revision A. These components were assembled and tested in a test fixture.

When pressure was applied, a high separating force was developed. This was determined to be caused by inadequate venting of the space between the cage and cylinder. The venting area was increased by slotting the end plate of the cage and chamfering its forward end. This eliminated the high separating force.

Torque testing of the cylinder and cage was conducted at various pressures with an orifice in the outlet line downstream of the fixture of a size which will pass rated flow at approximately 300 psi in the test fixture. Torque readings were obtained using hand held torque wrench and also using an electrically driven torque meter. Results of the test using the torque meter are included as Figure 15. The torques obtained indicate an opening torque on the cage, that is, the fluid tends to align the slot in the cage with the slot in the cylinder.

An effort was made to eliminate or reduce the magnitude of the torque by the following three methods.

(1) Shaping of the leading edge of the slot in the cage.

(2) Attaching a fence to the cage at two of the slots which protruded into the slot of the cylinder. The arrangement is shown in Figure 16. The fences produce an unbalanced pressure area which result in a closing torque when the slot in the cage is in the near closed position.

NO.	EER5716068		BY	WT	PAGE	16
REV LTR	NC					
DATE	1-19-72					

- (3) Attaching a shroud to the cage which directs the flow from the slots in a longitudinal direction. The shroud is pictured in Figure 17. Various positions of the shroud were tried relative to the slots in the cage.

The various devices tried in an effort to reduce the torque altered the shape of the torque-displacement curve but none showed a consistent improvement of the total torque range over the working angle of the assembly.

When parts became available to complete the assembly of a MFC, the prototype cylinder and cage in its unmodified form was used in the assembly. The assembly was tested over an inlet pressure range of 400-1000 psig and performed without any problem traceable to a torque on the cage. Further torque tests of the cylinder and cage were discontinued.

5.1.2 Prototype Bellows

A prototype bellows assembly was fabricated and filled with helium to a pressure of 112 psia at midstroke and 100 degrees F temperature. (The pressure was calculated to be the required charge pressure for an oxygen MFC without a flow sensitivity correction). The bellows was stroked using a spring tester and a force deflection-curve obtained both for increasing load and for decreasing load. From this curve the following data was obtained.

Force at midstroke: 225 lbs.

Spring rate of filled bellows, 75 degrees F = 835

Hysteresis: negligible

The prototype bellows was used in the prototype MFC assembly. The performance of this unit is shown in Figure 19.

5.2 Prototype MFC Testing

The first MFC was assembled using the prototype cage and cylinder, the prototype bellows assembly and the prototype belleville spring. It was tested in the test setup shown in Figure 19.

Pressure regulation performance of this unit is shown in Figure 19. Analysis of this data resulted in the following conclusions:

- (1) Scatter of data at a particular flow rate is approximately 12 psi (+ - 6 psi).
- (2) Decreasing the flow rate by changing the downstream orifice from .687 diameter to .624 diameter causes an upward shift in control pressure of approximately 20 psi at 0 degrees F.

REV LTR	NC				
DATE	1-19-72				

- (3) The slope of the pressure vs. temperature curve at constant flow rate is less steep than the target curve. The target curve shown is obtained from the oxygen curve of Figure 3 less (a) 14.7 psi to convert it to a sea level gage pressure reading) and (b) the velocity head in psi for rated flow in the outlet line where outlet pressure is measured.

The prototype MFC was cycled 1000 times at room temperatures using a solenoid pilot valve. Inlet pressure was 400 psia. Following the cycle test the unit was disassembled and inspected. No damage was detected as a result of the cycle test.

5.3 Pre Production Testing

Analysis of the results of testing the prototype components and the prototype MFC assembly led to certain design changes. The bellows assembly charge pressure was increased to increase the slope of the pressure regulation curve and the cage and cylinder were altered for increased strength and improved performance.

The cage wall thickness was increased to strengthen it where the prototype cage had proved weak. The journal of the bearing was increased in section to reduce the deflection resulting from the linkage loads.

The radial clearance between the cage and cylinder was decreased and the length of the slots were decreased to reduce the fluid torque effects and consequently improve precision. The cage and cylinder were made in a four-slot and six-slot version. Comparative tests showed the six slot version markedly superior. All testing of the four-slot version was discontinued and six-slot cages were ordered for all production units.

At this time it was decided that remaining performance testing would be conducted over a 500-700 psi inlet pressure range rather than 400-2000 psi design range. The limited inlet pressure range avoids the inlet pressures which cause a still unexplained rise in outlet pressure of approximately 20 psi. The inlet pressure range of 500 to 700 psig is consistent with use of a roughing regulator upstream of the MFC.

The body which had been used on the prototype MFC was modified by adding a second outlet port. This was accomplished by drilling a hole in the body downstream of the cylinder and cage assembly, tapping a 1-inch pipe thread and installing an AN816-16 nipple. The body was used in a complete assembly using a six slot cage and cylinder configuration. The original outlet port was capped

NO.	EER5716068		BY	WT	PAGE	18
REV LTR	NC					
DATE	1-19-72					

and the unit placed in the test setup with the downstream system, including the orifice, connected to the new outlet port. In this configuration the flow passes from the cylinder and cage to the outlet, bypassing the belleville spring and bellows. Outlet pressure was modified at the port in the original outlet flange which opens to the region of the bellows. The bellows assembly used was charged to 135 psia at 100 degrees F, midstroke position.

The modified assembly was tested with orifices of .687 diameter and .562 diameter installed in the outlet. The resulting pressure regulator curves are shown in Figure 20. The curve for the .687 diameter orifice shows the outlet pressure to be approximately 42 psi higher at 0° F than when tested in the conventional manner. This increase results from (1) elimination of the closing force on the belleville spring and (2) measurement of the pressure at a location which is at the same pressure level as the bellows. The tests also show an upward shift in outlet pressure of approximately 9 psi (at 0° F) when the orifice in the outlet is changed from .687 to .562 diameter. This is a smaller shift than occurs when testing the unit in the conventional manner but is greater than anticipated.

Analysis of the test data resulted in the revised bellows charge levels described in paragraph 3.2. A bellows charged to the new level was assembled in a MFC using an unmodified body. The pressure regulation curves resulting are shown in Figure 21 for an orifice size of .687 and .624 diameter. A point on the rated flow performance curve is obtained where the test points taken for a .687 diameter orifice cross the rated flow line for that orifice. A second point on the rated flow performance curve is obtained where the test points for the .624 diameter orifice cross the rated flow line for that orifice. A line joining these two points is the rated flow performance curve. This curve shows the correct slope for an oxygen MFC and the correct pressure level.

The best transient temperature test occurred during test of this unit. The inlet temperature was suddenly lowered by approximately 300° F. The recorder trace obtained is reproduced as Figure 22. It shows inlet temperature, outlet temperature and outlet pressure vs. time. The test was conducted with a .624 diameter orifice in the outlet line and an inlet pressure of approximately 600 psig. The trace shows the inlet temperature changing more rapidly than the temperature measured at the bellows which is to be expected since there is some warming of the gas as it passes through the MFC. The outlet pressure responds more rapidly than either temperature which indicates that the charged bellows responds more rapidly than the thermocouples used in the test.

The data from Figure 22 is reproduced on a larger scale in Figure 23. Plotted also in Figure 23 is the transient curve prepared from calculations for a step temperature change. (See paragraph 3.3 and Figure 10.)

The test curve covers a greater pressure range since it is a test with a .624 diameter orifice in the outlet line (hence the flow rate increases as the temperature decreases) rather than with constant rated flow throughout the temperature range. The test curve shows the outlet pressure to change more slowly than the calculated curve. Part of the difference is explained by the fact that (1) a true step temperature change was not obtained in the test and (2) some warming of the flow occurs between the inlet and the bellows which was not accounted for in the calculations.

NO.	EER5716068		BY	WT	PAGE	19
REV LTR	NC					
DATE	1-19-74					

An interesting recorder trace obtained with the preproduction unit by amplifying the outlet pressure signal. This trace is reproduced as Figure 24. It shows very clearly the variation in outlet pressure as the temperature varies. It also shows the outlet pressure responds more rapidly than does the thermocouple used to measure the temperature.

5.4 Acceptance Tests

Four MFC units were assembled in accordance with the Manufacturing Operations Routing for Part No. 5716068, a copy of which is included in the appendix. For each bellows assembly and each belleville spring used, a load deflection curve was obtained by use of a spring tester. These curves are included in the appendix. The curves show a belleville negative spring rate somewhat greater in magnitude than the bellows assembly positive spring rate. This results in a slightly negative spring rate of the MFC which is undesirable for stability. Instability did not prove to be a problem however during testing at limited inlet pressures (500-700 psig).

All production MFC units, adaptors and solenoid pilot valves were tested in accordance with PTS5716068. Copies of these documents are included in the appendix. Results of these tests are summarized below. Copies of actual data sheets are included in the appendix.

5.4.1

Leakage

Leakages recorded for the four production units are summarized in Table 1. External leakage occurred at the joint when the cap attaches to the body which sees inlet pressure, and at the joint where the housing attaches to the body, which sees outlet pressure. The seals used consist of a single piece Teflon jacket with an internal CRES expander spring and are standard parts obtained from Raco. Surfaces in contact with the seals have finishes and dimensions in accordance with the seal manufacturer's recommendations. Total external leakage at the limited inlet pressure is less than 10 sccm.

Internal leakage occurred at the poppet seat (which may have been augmented by leakage past two Raco seals which are potential parallel leakage within two light bands and with a finish of four micro inch, except for one oxygen MFC, S/N 02. This unit leaked excessively.

Another leakage recorded on the data sheets but not listed in Table 1 is the piston leakage. This is the leakage past the piston ring and occurs only when the MFC unit is open. This leakage passes through the solenoid pilot valve and into the MFC outlet, bypassing the throttling device. It produces no detectable effect on the performance of the MFC.

5.4.2

Pressure Response

A recorder trace obtained during a pressure response test is shown as Figure 25. Four inputs were monitored:

- (a) Solenoid voltage
- (b) Inlet pressure
- (c) Outlet pressure
- (d) Pressure in the shutoff piston chamber

5.4.2.1

Opening Response

When the solenoid pilot valve is energized it shuts off the fluid communication path from the MFC inlet to the shutoff valve piston chamber and opens a communication path from the piston chamber to the MFC outlet. The pressure in the chamber then blows down until the shutoff piston begins to move. Once the piston begins to move, the downstream face of the piston, unpressurized when closed, becomes pressurized. The increased area exposed to pressure produces sufficient force on the piston to open it fully without further flow of gas from the piston chamber.

NO.	EER5716068		BY	WT	PAGE	21
REV LTR	NC					
DATE	1-19-72					

The opening time can be considered to consist of four intervals:

- (1) Solenoid Response Time - the time required for the two-position solenoid pilot valve to shift position after energization. (60 milliseconds)
- (2) Blowdown Time - the time required to depressurize the piston chamber to the pressure at which the piston can begin to move. (60 milliseconds)
- (3) Piston Travel Time - the time required for the piston to travel sufficiently to pass rated flow. (20 milliseconds)
- (4) Controller Reaction Time - the time for the throttling element, which is initially fully open, to overshoot, recover, and achieve regulation. (20 milliseconds)

The times shown in parentheses are the times taken from the recorder traces of Figure 25.

5.4.2.2 Closing Response

When the solenoid pilot valve is de-energized it shuts off the fluid communication path between the piston chamber and the MFC outlet port and opens a path from the MFC inlet to the piston chamber. The pressure in the piston chamber then rises to near inlet pressure and is closed by the piston return spring. When the piston approaches the seat the pressure drop across the piston produces an additional closing force.

The closing time can be considered to consist of 4 intervals.

- (1) Solenoid Response Time: the time required for the two-position solenoid pilot valve to shift position after de-energization. (5 milliseconds)
- (2) Pressurization Time: the time required for the chamber to pressurize to the point when the spring can initiate closing. (25 milliseconds)
- (3) Spring Closure Time: the time required for the spring to return the piston from its fully open position to the point when the pressure drop across the piston aids closure. (115 milliseconds)
- (4) Pressure Assisted Closure Time: the time required for the piston to move the final distance under the influence of the pressure drop across the piston and, to a lesser extent, the spring force. (10 milliseconds)

These times shown in parentheses are the times taken from the recorder traces of Figure 25.

NO.	EER5716068	BY	WT	PAGE
REV LTR	NC			
DATE	1-19-72			

5.4.3 Control Pressure with Varying Inlet Pressure

Pressure regulation performance was obtained over an inlet pressure range up to 1000 psig with the temperature essentially constant. A typical trace obtained from one of the four units (an oxygen MFC, Serial No. 02) is included as Figure 26. This curve shows that the MFC controls outlet pressure high by as much as 20 psi when the inlet pressure is between 400 and 500 psig for both increasing and decreasing inlet pressure. The reason for this pressure rise was not established conclusively but is suspected to be associated with torqueon the cage. The outlet pressure is low also during increasing inlet pressure between 700 and 900 psig and during decreasing inlet pressure between 950 and 700 psig although the effect is not so great as at the low inlet pressures.

5.4.4 Control Pressure with Varying Temperature

Pressure regulation performance was obtained throughout the temperature range with the inlet pressure in the 500-700 psig range. Each unit was tested without thermal conditioning using a .687 diameter orifice in the outlet. An orifice of .624 inch diameter was substituted prior to the test runs in which thermal conditioning was accomplished. A curve plotted for one of the four units (an oxygen MFC, Serial No. 02) is shown on Figure 27. Similar curves for the remaining three units are included in the appendix. The curves show that the units were not adjusted as precisely as was the preproduction unit. (See Figure 21.) The slope of the constant flow curve does not match the target slope as well as did the preproduction unit.

5.4.5 Thermal Response

Thermal response was conducted on each unit and the results tabulated in Table 2. This shows the magnitude of the inlet temperature change resulting from a sudden opening of the liquid nitrogen supply and the time required for the outlet pressure to reach the new equilibrium pressure.

5.5 Design Verification Testing

One of the four units (a hydrogen MFC, Serial No. 01) was subjected to Design Verification Testing in accordance with DVT5716068, a copy of which is included in the appendix. Test results are summarized in Table 3. Copies of actual data sheets are included in the appendix.

5.5.1 Endurance Test

The unit was cycled with the solenoid pilot valve at an inlet pressure of 400 psig. A sufficiently small orifice was installed in the outlet to cause the throttling element to reach its fully restricted position each time the solenoid valve opened. Ten thousand cycles were imposed. Poppet leakage following the cycle test was approximately the same as before the test. The piston leakage increased but not sufficient to affect performance.

NO.	EER5716068		BY	WT	PAGE	23
REV LTR	NC					
DATE	1-19-72					

5.5.2

Pressure Drop Test

The pressure drop test was conducted at an outlet pressure well below the set pressure to assure that the throttling element was in its fully open position. At 100 ° F (outlet pressure of 360 psia) the test data indicates a pressure drop of 60 psi which exceeds the 40 psi design point. The excess pressure drop resulted from the changes to the cage and cylinder following the prototype tests, which decreased the open flow area. The pressure drop of the unit is adequate for the revised inlet pressure range (500 - 700 psig), which requires a pressure drop less than 155 psi at full flow.

5.6

Helium Test

One of the two hydrogen units (Serial No. 02) was tested for stability using helium as the flowing medium. The test setup was identical to that shown on Figure 18 except that a "six pack" of helium bottles manifolded together was connected to the MFC inlet in place of the gaseous nitrogen supply. No thermal conditioning was employed but the spherical pressure vessel was utilized (by opening ball valve B₂) to lengthen the time of the test run. This was necessary since the opening from the manifolded six pack was too small to meet the flow demand of the MFC. An orifice of .687 inch diameter was installed in the outlet for this test. The inlet pressure was approximately 600 psig. No audible instability was detected with helium as the test medium nor did the outlet pressure as monitored by the recorder indicate an instability. The length of the test run obtainable by this test method is too limited to establish conclusively that the MFC is stable with helium flowing.

NO	EER5716068		BY	WT	PAGE	24
REV LTR	NC					
DATE	1-19-72					

6.0 CONCLUSIONS AND RECOMMENDATIONS

6.1 The all mechanical mass flow controller can control outlet pressure within ± 1 percent over the entire temperature range (-250°F to $+100^{\circ}\text{F}$) provided the inlet pressure range is limited to 500-700 psig. Further development is recommended to increase the inlet pressure range without adversely affecting the control pressure band. The element in the MFC which requires improvement is the throttling device (the cylinder and cage).

6.2 The errors in mass flow control and mixture ratio resulting from a pressure control error of ± 1 percent were determined by analytical techniques. It is recommended that these errors be determined also during test firing of a rocket engine with the propellants supplied through two all mechanical MFC units.

6.3 The error in mass flow and mixture ratio resulting from an error in control pressure of $\pm 1\%$ is shown over the entire temperature range in Figure 28. The curve was calculated on the basis of a pressure drop through the fixed restriction of 60 psi (at 100°F). For a pressure drop of 120 psi the errors in mass flow and mixture ratios are less. These are plotted in Figure 29. It is recommended that the pressure drop allowable through the fixed restriction be reviewed to ascertain whether it can be increased and how much.

6.4 The design which was tested is flow sensitive. Its control pressure changes when the flow rate changes. This characteristic is undesirable in an application when one MFC unit supplies a cluster of rocket engines. The flow sensitivity can be considerably reduced, by redesigning so that the flow does not pass through the belleville spring. Additional improvement can be achieved by reducing the pressure drop between the throttling element and the outlet port. It is recommended that further work be performed to determine how much improvement is feasible.




FIGURE 1 PRINCIPLE OF ALL MECHANICAL MASS FLOW CONTROLLER

COMBUSTION CHAMBER PRESSURE VS TEMPERATURE
OF PROPELLANTS ENTERING CHAMBER : BOTH GASES
(HYDROGEN AND OXYGEN) ASSUMED AT SAME TEMPERATURE

$$P_c = P_c(560) \times \frac{T_{sp}(560)}{T_{sp}}$$

CHAMBER PRESSURE ~ PSIA

DESIGN POINT

300

200

400

600

800

PROPELLANT GAS TEMPERATURE, °R

FIGURE 2 COMBUSTION CHAMBER VARIATION WITH TEMPERATURE





FIGURE 3 SPECIFIC IMPULSE VARIATION WITH TEMPERATURE
PROPELLENT GAS INLET TEMPERATURE (°F)






FIGURE 5 SCHEMATIC DRAWING OF
MASS FLOW CONTROLLER




FIGURE 16 TOLERANCE OF CONTROL PRESSURE AT 100°F







FIGURE 17. TOLERANCE OF CONTROL PRESSURE AT -210°F

CONTROL PRESSURE = 2000

FIGURE 8 ALLOWABLE TOLERANCE BAND FOR MASS FLOW TOLERANCE OF $\pm 2\%$ OXYGEN AND $\pm 5\%$ HYDROGEN. PRESSURE SLOPE SHOWN IS FOR OXYGEN MFC.











FIGURE 12



SECTION A - A SCALE 2 1/4

ITEM NO.	DESCRIPTION	QTY	REF.
2	A REDRAWN REEL FOR SPL. PROJECT	1	44-7
3	- B REVISED ITEMS 4, 24, 2228 & 44	1	44-7
	ADDED ITEMS 16 THRU 50	1	44-7
	ADDED CIG. NO. 302	1	44-7

ITEM NO.	DESCRIPTION	QTY	REF.
1	AR M62095C LOCK WHEEL	1	49
1	AR 5716161 CHARGED BELLOWS	1	48
1	AR 5716160 CHARGED BELLOWS	1	48
1	AN950C6 WASHER	1	47
2	2 5716158 WASHER	2	C 16
4	4 AR 5716124-2-3-4 SHIM, SPIDER	4	B 45
3	3 B WASHER, SHIM SCREW	3	44
3	3 B WASHER, SHIM SCREW	3	43
3	3 B AN950D16 WASHER	3	43
2	2 ODS-10-030 BUSHING	2	SOUTHWEST PROD CO
3	3 ODS-4-030 BUSHING	3	- 42
1	1 161-01-500 SEAL	1	40
1	1 151-00-375 SEAL	1	39
1	1 170-04-375 SEAL	1	38
1	1 160-02-750 SEAL	1	37
1	1 MS-57155-500 WASHER	1	35
2	2 MS-21043-5 NUT	2	35
1	1 14321043-3 NUT	1	34
2	2 M24x83C6 SCREW	2	33
3	3 B WASHER, SHIM SCREW	3	32
2	2 B WASHER, SHIM SCREW	2	31
6	6 WASHER, SHIM SCREW	6	- 30
1	1 LC-063G-12 SPRING COMP	1	29
1	1 5716156 SEAL	1	C 28
1	1 1 WASHER, SHIM SCREW	1	- 27
2	2 5716105 SEAL ASSY, PISTON	2	C 26
1	1 5716107 BOLT, CLEVIS	1	C 25
2	2 5716106 WASHER, TEFON	2	B 24
4	4 AR 5716103-5-4 SHIM, BELLEVILLE	4	C 23
4	4 AR 5716104-5-4 SHIM, CLEVIS	4	B 22
1	1 5716108 SPRING, BELLEVILLE	1	C 21
1	1 5716101 RETAINER, BUSH	1	C 20
1	1 5716096 GUIDE, POPPET	1	C 19
1	1 5716084 PISTON	1	D 18
1	1 5716085 POPPET	1	C 17
1	1 5716059 GUIDE, FLOW	1	C 16
1	1 5716077 CLEVIS	1	C 15
1	1 5716098 RING, OUTER	1	B 14
1	1 5716096 RING, INNER	1	B 13
1	1 5716057 GUIDE, OUTER	1	C 12
1	1 5716095 GUIDE, INNER	1	C 11
1	1 5716094 STOP BELLEVILLE	1	C 10
1	1 5716092 NUT, SPIDER	1	C 9
1	1 5716093 SPIDER	1	C 8
1	1 5716071 LINK	1	D 7
1	1 5716059 CAGE	1	D 6
1	1 5716070 CYLINDER	1	D 5
1	1 5716157 BUSHING	1	C 4
1	1 5716083 CAP ASSY	1	D 3
1	1 5716090 HOUSING ASSY	1	D 2
1	1 5716082 BODY ASSY	1	E 1
1	1 5716101	1	-

ITEM NO.	DESCRIPTION	QTY	REF.
1	UNLESS OTHERWISE SPECIFIED CONTRACT NO.	1	156
2	ALL PARTS ARE TO BE PLATED IN ZINC, EXCEPT AS NOTED.	1	
3	ALL PARTS ARE TO BE PLATED IN ZINC, EXCEPT AS NOTED.	1	
4	ALL PARTS ARE TO BE PLATED IN ZINC, EXCEPT AS NOTED.	1	
5	ALL PARTS ARE TO BE PLATED IN ZINC, EXCEPT AS NOTED.	1	
6	ALL PARTS ARE TO BE PLATED IN ZINC, EXCEPT AS NOTED.	1	
7	ALL PARTS ARE TO BE PLATED IN ZINC, EXCEPT AS NOTED.	1	
8	ALL PARTS ARE TO BE PLATED IN ZINC, EXCEPT AS NOTED.	1	
9	ALL PARTS ARE TO BE PLATED IN ZINC, EXCEPT AS NOTED.	1	
10	ALL PARTS ARE TO BE PLATED IN ZINC, EXCEPT AS NOTED.	1	
11	ALL PARTS ARE TO BE PLATED IN ZINC, EXCEPT AS NOTED.	1	
12	ALL PARTS ARE TO BE PLATED IN ZINC, EXCEPT AS NOTED.	1	
13	ALL PARTS ARE TO BE PLATED IN ZINC, EXCEPT AS NOTED.	1	
14	ALL PARTS ARE TO BE PLATED IN ZINC, EXCEPT AS NOTED.	1	
15	ALL PARTS ARE TO BE PLATED IN ZINC, EXCEPT AS NOTED.	1	
16	ALL PARTS ARE TO BE PLATED IN ZINC, EXCEPT AS NOTED.	1	
17	ALL PARTS ARE TO BE PLATED IN ZINC, EXCEPT AS NOTED.	1	
18	ALL PARTS ARE TO BE PLATED IN ZINC, EXCEPT AS NOTED.	1	
19	ALL PARTS ARE TO BE PLATED IN ZINC, EXCEPT AS NOTED.	1	
20	ALL PARTS ARE TO BE PLATED IN ZINC, EXCEPT AS NOTED.	1	
21	ALL PARTS ARE TO BE PLATED IN ZINC, EXCEPT AS NOTED.	1	
22	ALL PARTS ARE TO BE PLATED IN ZINC, EXCEPT AS NOTED.	1	
23	ALL PARTS ARE TO BE PLATED IN ZINC, EXCEPT AS NOTED.	1	
24	ALL PARTS ARE TO BE PLATED IN ZINC, EXCEPT AS NOTED.	1	
25	ALL PARTS ARE TO BE PLATED IN ZINC, EXCEPT AS NOTED.	1	
26	ALL PARTS ARE TO BE PLATED IN ZINC, EXCEPT AS NOTED.	1	
27	ALL PARTS ARE TO BE PLATED IN ZINC, EXCEPT AS NOTED.	1	
28	ALL PARTS ARE TO BE PLATED IN ZINC, EXCEPT AS NOTED.	1	
29	ALL PARTS ARE TO BE PLATED IN ZINC, EXCEPT AS NOTED.	1	
30	ALL PARTS ARE TO BE PLATED IN ZINC, EXCEPT AS NOTED.	1	
31	ALL PARTS ARE TO BE PLATED IN ZINC, EXCEPT AS NOTED.	1	
32	ALL PARTS ARE TO BE PLATED IN ZINC, EXCEPT AS NOTED.	1	
33	ALL PARTS ARE TO BE PLATED IN ZINC, EXCEPT AS NOTED.	1	
34	ALL PARTS ARE TO BE PLATED IN ZINC, EXCEPT AS NOTED.	1	
35	ALL PARTS ARE TO BE PLATED IN ZINC, EXCEPT AS NOTED.	1	
36	ALL PARTS ARE TO BE PLATED IN ZINC, EXCEPT AS NOTED.	1	
37	ALL PARTS ARE TO BE PLATED IN ZINC, EXCEPT AS NOTED.	1	
38	ALL PARTS ARE TO BE PLATED IN ZINC, EXCEPT AS NOTED.	1	
39	ALL PARTS ARE TO BE PLATED IN ZINC, EXCEPT AS NOTED.	1	
40	ALL PARTS ARE TO BE PLATED IN ZINC, EXCEPT AS NOTED.	1	
41	ALL PARTS ARE TO BE PLATED IN ZINC, EXCEPT AS NOTED.	1	
42	ALL PARTS ARE TO BE PLATED IN ZINC, EXCEPT AS NOTED.	1	
43	ALL PARTS ARE TO BE PLATED IN ZINC, EXCEPT AS NOTED.	1	
44	ALL PARTS ARE TO BE PLATED IN ZINC, EXCEPT AS NOTED.	1	
45	ALL PARTS ARE TO BE PLATED IN ZINC, EXCEPT AS NOTED.	1	
46	ALL PARTS ARE TO BE PLATED IN ZINC, EXCEPT AS NOTED.	1	
47	ALL PARTS ARE TO BE PLATED IN ZINC, EXCEPT AS NOTED.	1	
48	ALL PARTS ARE TO BE PLATED IN ZINC, EXCEPT AS NOTED.	1	
49	ALL PARTS ARE TO BE PLATED IN ZINC, EXCEPT AS NOTED.	1	
50	ALL PARTS ARE TO BE PLATED IN ZINC, EXCEPT AS NOTED.	1	


ITEM NO.	DESCRIPTION	QTY	REF.
1	PARTS MANDATED FROM MASS FLOW CONTROLLER DIRECT OPERATING TUBE	1	
2	PARTS MANDATED FROM MASS FLOW CONTROLLER DIRECT OPERATING TUBE	1	
3	PARTS MANDATED FROM MASS FLOW CONTROLLER DIRECT OPERATING TUBE	1	
4	PARTS MANDATED FROM MASS FLOW CONTROLLER DIRECT OPERATING TUBE	1	
5	PARTS MANDATED FROM MASS FLOW CONTROLLER DIRECT OPERATING TUBE	1	
6	PARTS MANDATED FROM MASS FLOW CONTROLLER DIRECT OPERATING TUBE	1	
7	PARTS MANDATED FROM MASS FLOW CONTROLLER DIRECT OPERATING TUBE	1	
8	PARTS MANDATED FROM MASS FLOW CONTROLLER DIRECT OPERATING TUBE	1	
9	PARTS MANDATED FROM MASS FLOW CONTROLLER DIRECT OPERATING TUBE	1	
10	PARTS MANDATED FROM MASS FLOW CONTROLLER DIRECT OPERATING TUBE	1	
11	PARTS MANDATED FROM MASS FLOW CONTROLLER DIRECT OPERATING TUBE	1	
12	PARTS MANDATED FROM MASS FLOW CONTROLLER DIRECT OPERATING TUBE	1	
13	PARTS MANDATED FROM MASS FLOW CONTROLLER DIRECT OPERATING TUBE	1	
14	PARTS MANDATED FROM MASS FLOW CONTROLLER DIRECT OPERATING TUBE	1	
15	PARTS MANDATED FROM MASS FLOW CONTROLLER DIRECT OPERATING TUBE	1	
16	PARTS MANDATED FROM MASS FLOW CONTROLLER DIRECT OPERATING TUBE	1	
17	PARTS MANDATED FROM MASS FLOW CONTROLLER DIRECT OPERATING TUBE	1	
18	PARTS MANDATED FROM MASS FLOW CONTROLLER DIRECT OPERATING TUBE	1	
19	PARTS MANDATED FROM MASS FLOW CONTROLLER DIRECT OPERATING TUBE	1	
20	PARTS MANDATED FROM MASS FLOW CONTROLLER DIRECT OPERATING TUBE	1	
21	PARTS MANDATED FROM MASS FLOW CONTROLLER DIRECT OPERATING TUBE	1	
22	PARTS MANDATED FROM MASS FLOW CONTROLLER DIRECT OPERATING TUBE	1	
23	PARTS MANDATED FROM MASS FLOW CONTROLLER DIRECT OPERATING TUBE	1	
24	PARTS MANDATED FROM MASS FLOW CONTROLLER DIRECT OPERATING TUBE	1	
25	PARTS MANDATED FROM MASS FLOW CONTROLLER DIRECT OPERATING TUBE	1	
26	PARTS MANDATED FROM MASS FLOW CONTROLLER DIRECT OPERATING TUBE	1	
27	PARTS MANDATED FROM MASS FLOW CONTROLLER DIRECT OPERATING TUBE	1	
28	PARTS MANDATED FROM MASS FLOW CONTROLLER DIRECT OPERATING TUBE	1	
29	PARTS MANDATED FROM MASS FLOW CONTROLLER DIRECT OPERATING TUBE	1	
30	PARTS MANDATED FROM MASS FLOW CONTROLLER DIRECT OPERATING TUBE	1	
31	PARTS MANDATED FROM MASS FLOW CONTROLLER DIRECT OPERATING TUBE	1	
32	PARTS MANDATED FROM MASS FLOW CONTROLLER DIRECT OPERATING TUBE	1	
33	PARTS MANDATED FROM MASS FLOW CONTROLLER DIRECT OPERATING TUBE	1	
34	PARTS MANDATED FROM MASS FLOW CONTROLLER DIRECT OPERATING TUBE	1	
35	PARTS MANDATED FROM MASS FLOW CONTROLLER DIRECT OPERATING TUBE	1	
36	PARTS MANDATED FROM MASS FLOW CONTROLLER DIRECT OPERATING TUBE	1	
37	PARTS MANDATED FROM MASS FLOW CONTROLLER DIRECT OPERATING TUBE	1	
38	PARTS MANDATED FROM MASS FLOW CONTROLLER DIRECT OPERATING TUBE	1	
39	PARTS MANDATED FROM MASS FLOW CONTROLLER DIRECT OPERATING TUBE	1	
40	PARTS MANDATED FROM MASS FLOW CONTROLLER DIRECT OPERATING TUBE	1	
41	PARTS MANDATED FROM MASS FLOW CONTROLLER DIRECT OPERATING TUBE	1	
42	PARTS MANDATED FROM MASS FLOW CONTROLLER DIRECT OPERATING TUBE	1	
43	PARTS MANDATED FROM MASS FLOW CONTROLLER DIRECT OPERATING TUBE	1	
44	PARTS MANDATED FROM MASS FLOW CONTROLLER DIRECT OPERATING TUBE	1	
45	PARTS MANDATED FROM MASS FLOW CONTROLLER DIRECT OPERATING TUBE	1	
46	PARTS MANDATED FROM MASS FLOW CONTROLLER DIRECT OPERATING TUBE	1	
47	PARTS MANDATED FROM MASS FLOW CONTROLLER DIRECT OPERATING TUBE	1	
48	PARTS MANDATED FROM MASS FLOW CONTROLLER DIRECT OPERATING TUBE	1	
49	PARTS MANDATED FROM MASS FLOW CONTROLLER DIRECT OPERATING TUBE	1	
50	PARTS MANDATED FROM MASS FLOW CONTROLLER DIRECT OPERATING TUBE	1	

ITEM NO.	DESCRIPTION	QTY	REF.
1	PREP FOR BURN, SHOT	1	
2	PREP FOR BURN, SHOT	1	
3	PREP FOR BURN, SHOT	1	
4	PREP FOR BURN, SHOT	1	
5	PREP FOR BURN, SHOT	1	
6	PREP FOR BURN, SHOT	1	
7	PREP FOR BURN, SHOT	1	
8	PREP FOR BURN, SHOT	1	
9	PREP FOR BURN, SHOT	1	
10	PREP FOR BURN, SHOT	1	
11	PREP FOR BURN, SHOT	1	
12	PREP FOR BURN, SHOT	1	
13	PREP FOR BURN, SHOT	1	
14	PREP FOR BURN, SHOT	1	
15	PREP FOR BURN, SHOT	1	
16	PREP FOR BURN, SHOT	1	
17	PREP FOR BURN, SHOT	1	
18	PREP FOR BURN, SHOT	1	
19	PREP FOR BURN, SHOT	1	
20	PREP FOR BURN, SHOT	1	
21	PREP FOR BURN, SHOT	1	
22	PREP FOR BURN, SHOT	1	
23	PREP FOR BURN, SHOT	1	
24	PREP FOR BURN, SHOT	1	
25	PREP FOR BURN, SHOT	1	
26	PREP FOR BURN, SHOT	1	
27	PREP FOR BURN, SHOT	1	
28	PREP FOR BURN, SHOT	1	
29	PREP FOR BURN, SHOT	1	
30	PREP FOR BURN, SHOT	1	
31	PREP FOR BURN, SHOT	1	
32	PREP FOR BURN, SHOT	1	
33	PREP FOR BURN, SHOT	1	
34	PREP FOR BURN, SHOT	1	
35	PREP FOR BURN, SHOT	1	
36	PREP FOR BURN, SHOT	1	
37	PREP FOR BURN, SHOT	1	
38	PREP FOR BURN, SHOT	1	
39	PREP FOR BURN, SHOT	1	
40	PREP FOR BURN, SHOT	1	
41	PREP FOR BURN, SHOT	1	
42	PREP FOR BURN, SHOT	1	
43	PREP FOR BURN, SHOT	1	
44	PREP FOR BURN, SHOT	1	
45	PREP FOR BURN, SHOT	1	
46	PREP FOR BURN, SHOT	1	
47	PREP FOR BURN, SHOT	1	
48	PREP FOR BURN, SHOT	1	
49	PREP FOR BURN, SHOT	1	
50	PREP FOR BURN, SHOT	1	

ITEM NO.	DESCRIPTION	QTY	REF.
1	HEAT TRAY	1	
2	USED OR	1	
3	NOT USED	1	
4	NOT USED	1	
5	NOT USED	1	
6	NOT USED	1	
7	NOT USED	1	
8	NOT USED	1	
9	NOT USED	1	
10	NOT USED	1	
11	NOT USED	1	
12	NOT USED	1	
13	NOT USED	1	
14	NOT USED	1	
15	NOT USED	1	
16	NOT USED	1	
17	NOT USED	1	
18	NOT USED	1	
19	NOT USED	1	
20	NOT USED	1	
21	NOT USED	1	
22	NOT USED	1	
23	NOT USED	1	
24	NOT USED	1	
25	NOT USED	1	
26	NOT USED	1	
27	NOT USED	1	
28	NOT USED	1	
29	NOT USED	1	
30	NOT USED	1	
31	NOT USED	1	
32	NOT USED	1	
33	NOT USED	1	
34	NOT USED	1	
35	NOT USED	1	
36	NOT USED	1	
37	NOT USED	1	
38	NOT USED	1	
39	NOT USED	1	
40	NOT USED	1	

ITEM NO.	DESCRIPTION	QTY	REF.
1	NOT USED	1	
2	NOT USED	1	
3	NOT USED	1	
4	NOT USED	1	
5	NOT USED	1	
6	NOT USED	1	
7	NOT USED	1	
8	NOT USED	1	
9	NOT USED	1	
10	NOT USED	1	
11	NOT USED	1	
12	NOT USED	1	
13	NOT USED	1	
14	NOT USED	1	
15	NOT USED	1	
16	NOT USED	1	
17	NOT USED	1	
18	NOT USED	1	
19	NOT USED	1	
20	NOT USED	1	
21	NOT USED	1	
22	NOT USED	1	
23	NOT USED	1	
24	NOT USED	1	
25	NOT USED	1	
26	NOT USED	1	
27	NOT USED	1	
28	NOT USED	1	
29	NOT USED	1	
30	NOT USED	1	
31	NOT USED	1	
32	NOT USED	1	
33	NOT USED	1	
34	NOT USED	1	
35	NOT USED	1	
36	NOT USED	1	
37	NOT USED	1	
38	NOT USED	1	
39	NOT USED	1	
40	NOT USED	1	

ITEM NO.	DESCRIPTION	QTY	REF.
1	NOT USED	1	
2	NOT USED	1	
3	NOT USED	1	
4	NOT USED	1	
5	NOT USED	1	
6	NOT USED	1	
7	NOT USED	1	
8	NOT USED	1	
9	NOT USED	1	
10	NOT USED	1	
11	NOT USED	1	
12	NOT USED	1	
13	NOT USED	1	
14	NOT USED	1	



1. SAFETY FACTORS BASED ON ULTIMATE STRENGTHS OF MATERIALS AT PRESSURES INDICATED

CRES 347: 75000 PSI ULTIMATE

AL ALY 6061: 45000 PSI ULTIMATE

AL ALY 356T6: 33000 PSI ULTIMATE

2. STRESSES CALCULATED PER ASME CODE

FIGURE 13 SAFETY FACTORS FOR FLANGES OF MFC




FIGURE 14 FLOW AREA VS ANGULAR ROTATION




FIGURE 15 TORQUE ON PROTOTYPE CAGE DURING ROTATION




FIGURE 16 PROTOTYPE CAGE AND CYLINDER WITH FENCE




FIGURE 17 PROTOTYPE CAGE AND CYLINDER WITH SHROUD







FIGURE 18 SETUP FOR MFC TESTS










FIGURE 22 RECORDER TRACE OF TRANSIENT, PREPRODUCTION MFC




FIGURE 2.3 COMPARISON OF TEST TRACE WITH CALCULATED CURVE




FIGURE 24 RECORDER TRACE FROM TEST OF PREPRODUCTION MFC









FIGURE 25 PRESSURE RESPONSE

H₂ MFC, S/N 01

OUTLET TEMPERATURE



INLET PRESSURE



OUTLET PRESSURE






FIG 26 OUTLET PRESSURE WITH VARYING INLET PRESSURE


O₂ MFC, S/N 02





CONTROLLER WHICH MAINTAINS PRESSURE FROM MECHANICAL MASS FLOW

FIGURE 2



PRESSURE, PERCENT OF NOMINAL

CHANGES AND OSCILLATIONS
MAY BE ELIMINATED

PRESSURE REPORT

OFF MIXTURE REPORT

CAT 100 OF THERMOCOUPLE
LOCATION 40 & 120 PSI

CONDITIONS: GATE = 1.0 NOMINAL

		LEAKAGE, SCCM (TEST MEDIUM: GN ₂)			
EXTERNAL LEAKAGE	PRESSURE PSIG	HYDROGEN MFC P/N 5716068 - 101		OXYGEN MFC P/N 5716068 - 102	
		S/N 01	S/N 02	S/N 01	S/N 02
CAP FLANGE	1000	10	5	8	8
	2000	232	13	15	56
	400	<1	0	2	0
HOUSING FLANGE	3000	0	0	0	0
	400				
SOLENOID VALVE	3000	0	0	0	0
	400				
	1000				
INTERNAL LEAKAGE	2000	1375	1520	2315	40 000
	400	50	34	365	9000
	1000	330	420	1140	24000
POPPET	3000	0	0	0	0
	2000				
SOLENOID VALVE ENERGIZED	3000	0	0	0	0
	3000	0	0	0	0

TABLE I RESULTS OF LEAKAGE TESTS OF MASS FLOW CONTROLLERS

INTERNAL (POPPET) LEAKAGE, SCCM GN₂

INLET PRESSURE PSIG	BEFORE CYCLES	AFTER 10 000 CYCLES
400	50	45
1000	330	500
2000	1375	1300

PRESSURE DROP THROUGH FULLY OPEN MFC

 $\sigma \Delta P = 1400$ PSI AT RATED FLOW

$$\sigma = \frac{\text{DENSITY OF GN}_2 \text{ AT MFC OUTLET}}{\text{DENSITY OF GN}_2 \text{ AT 1 ATMOSPHERE, } 70^\circ\text{F}}$$

TABLE 2 SUMMARY OF DVT TEST RESULTS

	TEMPERATURE CHANGE, °F	CONTROL PRESSURE CHANGE, PSI	TIME REQ'D, SECS
HYDROGEN MFC 5716068 - 101			
S/N 01	- 170	- 23	0.8
S/N 02	- 242	- 25	1.3
OXYGEN MFC 5716068 - 102			
S/N 01	- 132	- 20	0.6
S/N 02	- 125	- 12	0.8

TABLE 3 RESULTS OF THERMAL RESPONSE TESTS
OF MASS FLOW CONTROLLERS

SYSTEMS DIVISION
PARKER HANNIFIN

NO. EER5716068 BY WT PAGE A-1

REV LTR	NC	-				
DATE	1-19-72					

APPENDIX A

MANUFACTURING OPERATION ROUTING

for P/N 5716068

MFG OPERATION ROUTING - SYSTEMS DIVISION

Part No.

5716063-102

Rev

B

Prepared By *E. M. E.*Date *7/2/71*Appd By *W. G. Z.*Date *7/2/71*Appd By *W. G. Z.*Date *7/2/71*No. Req *1*Start Date *7/2/71*Due Date *7/2/71*Planner *W. G. Z.*Project *W. G. Z.*Task *1*C. E. *1*Control Number *156*Next Assy *None*End Item *None*Material and Specification *PCB ASSY PARTS LIST*

Stock Required

REVISIONS

REV

DATE

MFG OPERATION ROUTING - OPERATION SEQUENCE SHEET

3/16/06 0-100

Oper No.	Dept./No.	Setup	Run	MACHINE AND OPERATION DESCRIPTION	Tools, Gages and Remarks	Oper and Insp Stamp	Date	Qty Comp	Qty Rej
20 (CONTINUED) C				CLEANING USED IN CLEAN ROOM					
				BIGGY SHAL BE CLEANED IN ACCORDANCE WITH OTHER STANDARDS					
				IN OP. 80.					
				D. ALL PARTS IN ALL CATAGORIES SHOULD BE BLOCK LIFT INSPECTED AFTER CLEANING.					
				E. REMOVE ONE OIL FROM BOLTS WITH WRENCH 5.5 BOLTS					
				IN OP. 80.					
				F. DO NOT SCREW BOLTS ON PANTS WITH 5.5 BOLTS					
				G. DO NOT REMOVE TASSON BOLTS UNLESS SPARES OR REPAIRS ASK					

MFG OPERATION ROUTING - OPERATION SEQUENCE SHEET

5716068-102

Oper No.	Dept No.	Setup	Run	MACHINE AND OPERATION DESCRIPTION	Tools, Gages and Remarks	Oper and Insp Stamp	Date	Qty Comp	Qty Rej
25	110			CLEAN VALVE PARTS AS FOLLOWS:					
				GROUP 'A' - NON METALLIC PARTS					
				ALL NON METALLIC PARTS SUCH AS 'O' RINGS, SEALS, ETC., SHALL BE CLEANED IN TUBES #215 WITH SOFT NYLON BRUSH & RINSED IN D.I. WATER. FINISH DRIED IN FLOOR & DRY BOX.					
				GROUP 'B' - METALLIC PARTS					
				All METALLIC PARTS SHALL BE WASH DEGREASED IN TURSON. BURST LIGHTLY TO REMOVE LOOSE PARTICLES.					
				GROUP 'C' - STAINLESS STEEL PARTS					
				TOUCH SCREEN HYGIENE WIPER DISINFECT BY ST. STE. & PLATE. PARTS SHOULD NOT EXPOSED TO AIR IN THIS ENVIRONMENT. DO NOT SCRATCH PARTS WITH ST. STE. HANDLES. SCRUB IN TUBES #215 & PLATES IN D.I. WATER. POLISH PARTS WITH WIPER OR BURST. DRY PARTS (1) HR. @ 150°F CUT LIGHT INSPECT AND PARTS IS TO BE INSPECTED					

MFG OPERATION ROUTING - OPERATION SEQUENCE SHEET

Part No.

5716068-102

EER5716068

A-6

Oper No.	Dept No.	Setup	Run	MACHINE AND OPERATION DESCRIPTION	Tools, Gages and Remarks	Oper and Inep Stamp	Date	Qty Comp	Qty Rej
30	120	A.	Sonic clean in feedon blocks 'A' & 'C' only. Clean block 'B' (INCORRECTED PARTS) WITH FRESH SPRAY RINSE. /ENCLASSMENT BLOCK 'B' PARTS MAY BE SONIC CLEANED IN FEEDON FOR 30 SECONDS MAX.						
		B.	RINSE EACH BLOCK WITH FRESH WATER 1000 ML SAME AS TOTAL. WEIGHT PER E55-15 LEVEL III. RECORD BELOW.						
			PARTICLE SIZE	2500	ACTUAL				
			175 - 200	10					
			200 - 2500	2					
			2500 & UP	0					
			BLOCKS. SUCCESS = 2 50. PT.						
			1/4" TEST ARE E55-15 AREA. 5.2 - 2 1/2 POUNDS						
		C.	DO 200 BLOCKS IN VACUUM OVER 110° TO 120° WITH 28.5" VACUUM. SEE (1) NO. (REC: E55-15 Part. 5.5)						

Oper No.	Dept No.	Setup	Run	MACHINE AND OPERATION DESCRIPTION	Tools, Gages and Remarks	Oper and Insp Stamp	Date	Qty Comp	Qty Rej
35 120				LOCKESE ALL PARTS IN POSITION & PLACE ON TOPPS TO ASSEMBLY AT OP. 130.					
40 130				CAGE - CYLINDER BUSHING ASSY. a. INSTALL BUSHINGS, ITEM 4, ON CYLINDER. ITEM 5, INSTANTIC WASHER ITEM #6. WEAD BUSHING WITH ELASTIC BAND #2 ADJUSTMENT. TO CONGESSION ON CYLINDER SMART. SURFACE CLEANER WITH BUSHING IN WIND WIREOGEN. REMOVE SCREW LINE & BOLT PLATE THE ELASTIC BAND. RIGIDLY & PERTINENTLY PRESS THIS CAGE ONTO THIS CYLINDER & BUSHING. b. WORK THE CYLINDER & CAGE BACK & FORWARD SEVERAL TIMES. AT THIS DO NOT RECENT RESET - HEAT THE ASSSEMBLY TO 500-550°F 15°C 30 MINUTES. LONG TIME PERMIT OPEN & CLOCK THIS PERIOD AS 10185 WALL & SPARE HGT.					

MFG OPERATION ROUTING - OPERATION SEQUENCE SHEET

Part No.

5716068-102

EER5716068

A-8

Oper No.	Dept No.	Setup	Run	MACHINE AND OPERATION DESCRIPTION	Tools, Gages and Remarks	Oper and Insp Stamp	Date	Qty Comp	Qty Rej
40 (continued)				<p>COOC TO BOOM TETTE. PARTS SUPPORT WAV OF PLESS. REMOVE THE CATER FROM THE CHINOSSE & CLEAN UP AND EXCESS BUILDING OR MESSAGE PARTICLESS.</p> <p>C- ASSISTANT THE CAT TO THE CHINOSSE, W/STYL W/ASSISTANT 17809 51, 50PC/PC 17809 28, WASHOE 17809 47 & SCREEN 17809 27. TOEBOUR SCREEN TO 20-25 NEW CBS. & SAFETY W/08.</p>					
45	100			<p>ASSISTANT LINNAGE</p> <p>O ASSISTANT:</p> <p>BUSINESS 2835-10-030 17809 42, 70</p> <p>LINE 5716071 17809 7. ASSISTANT.</p> <p>CLOWS BOOT 5716107 17809 25 &</p> <p>CLOAS 5716069 17809 6 70</p> <p>ASSISTANT TO PIT ALONES GROOMS CLOTHES. WORK BACK & ETCND CLOTHES.</p>	3'800.0051 -2 W/STYL W/ASSISTANT 500L5				

MFG OPERATION ROUTING - OPERATION SEQUENCE SHEET

Part No.

5716068-102

EER5716068

A-9

SHEET 1 OF 1

Oper No.	Dept No.	Setup Run	MACHINE AND OPERATION DESCRIPTION	Tools, Gages and Remarks	Oper and Insp Stamp	Date	Qty Comp	Qty Rej
45 (continued)	8.	BOSCH. CLEVIS 5716077, ITEM 15, TELLON WASHER 571606, ITEM 24, CLEVIS BOLT 571607, ITEM 25, WASHER MS15795-808, ITEM 36 & NUT MS21043-3, ITEM 34 PER 5/.	LOCK THE ASSEMBLY WITH PLATES ONE PLATE. THICKNESS TO 20.25 INCHES. C- PER SECTION SHEET 9 - ASSEMBLE WHEEL GUIDE 5716095, ITEM 11, TO THROAD ON CLEVIS # TWO UNTIL WHEEL GUIDE BOTTOMS ON CLEVIS SHOULDER. MEASURE # BOLTS 1/4 IN. PER SIDE SECTION 9. D. UNTHREAD WHEEL GUIDE HOSE. WHICH IS 5716050-1793 PLACE SIDE ASSY IN FIREBOX WITH PLATE THAT LINE BUSHING SEE STANCHION 2. THAT SIDE WHEEL GUIDE WITH IT BOTTOMS ON FIREBOX. MEASURE PLATE TO 2 IN. E. SUBTRACT 2.4 IN. FROM 1/4 IN. # BOLTS ACTUAL 5.0 IN. (NUMBER OF SPLINES EACH)					

MFG OPERATION ROUTING - SKETCH SHEET


Part No.

5716068-102

EER5716068

A-10

Oper No.	Dept No.	Setup	Run	MACHINE AND OPERATION DESCRIPTION
45 (cont'd)				f. Assm. Reorder number or S/N/M# 565-0-1793 5716104 to equal 5" dim. HAND MIGRATION GUIDE & CLOSUS.



MFG OPERATION ROUTING - OPERATION SEQUENCE SHEET

Part No.

5716068-102

MFG OPERATION ROUTING - OPERATION SEQUENCE SHEET

Part No.

5716068-102

EER5716068

A-12

Oper No.	Dept No.	Setup	Run	MACHINE AND OPERATION DESCRIPTION	Tools, Gages and Remarks	Oper and Inspec Stamp	Date	Qty Comp	Qty Rej
60 (CONTINUED)	B.	Install fixture, item 22, (AS ATTACHED IN O&P. #5) ON CLEVIS, ITEM 15 & SCREW ON INSIDE GUARD, ITEM 11, INSIDE GUARD MOUNT.							
C.				W/TH THE INSIDE GUARD MOUNT THROW ON THE SIDE PACK & RESTING ON THE BODY STOP, THE LARGE SLOTS IN THE CYLINDER & CASE SHOULD BE FULLY OPENED.					
D.				PLACE INNER PARTS, ITEM 13, ON INSIDE GUARD, ITEM 11. MOUNT GAGE RING ON TOP OF BODY PART SCOTCH & MEASURE TO END DIM 'A' - 565 SCOTCH SHOT 12.	565-0-120 Gage Ring				
E.				PER SCOTCH SHOT 13. PULL OVER. 60-0 & SECOND E' DM. ON SCOTCH SHOT.					
F.				PULL SHOT OVER SHOT 13. PULL OVER OVER. GO & RECORD '5' OUT. (TAKING THIS OVER'S CODE.)					


MFG OPERATION ROUTING - SKETCH SHEET

CONTINUUM

Part No.

5716068-102

Oper No.	Dept No.	Setup	Run	MACHINE AND OPERATION DESCRIPTION	Tools, Gages and Remarks	Oper and Insp Stamp	Qty Comp	Qty Rej
60 (continued)				Weld case bottomed per spec. 60	Ferrum open.			



ABSTRACT CASE AND THICKNESS 'L'
& RECALL RESULT AS 'A'.

$$(B - \lambda I = 0)$$

MFG OPERATION ROUTING - SKETCH SHEET

Part No.

5716068-102

ASS. 60-E /WATER HEATING & ASSORTED
EQUIPMENT STORE, OUTLET STORE & OWNERS
HOME. Plaintiff claims \$1000.00 on Housine
of Ass. 60-E. Owner raised Deposition
of Plaintiff and record shows no Housine
of Ass. 60-E.

$$D \cdot t_4 = E$$

The diagram illustrates a mechanical assembly for measuring thickness. It features a base plate (1) with a stepped profile. A gauge plate (2) is positioned above the base plate, secured by a lock nut (3). The gauge plate has a central slot (4) and a side slot (5). A dial caliper (6) is used to measure the distance between the top surface of the base plate and the bottom edge of the gauge plate. A dial indicator (7) is also shown, positioned to measure the thickness of the gauge plate at its center. Labels include:
 - "Gauge thickness as measured on gauge plate" (referring to the measurement with the dial caliper)
 - "DIAL INDICATOR" (referring to the dial indicator measurement)
 - "LOCK NUT" (referring to the lock nut securing the gauge plate)
 - "Gauge plate" (referring to the plate being measured)
 - "Base plate" (referring to the plate being measured)
 - "DIAL CALIPER" (referring to the dial caliper measurement)
 - "SLOPES" (referring to the stepped profile of the base plate)

0880.60-1.

$A - \delta = \text{AVAILABILITY}$ SPACE FOR
 $\text{REINVENTION} = T$

Total = .168
Bellville ~~total~~
Total = .090

$$S = S_{\text{sums}}$$

EER5716068

MFG OPERATION ROUTING - OPERATION SEQUENCE SHEET


Part No.

5716068-102

CONTROL NUMBER

EER5716068

A-15

Oper No.	Dept No.	Setup	Run	MACHINE AND OPERATION DESCRIPTION	Tools, Gages and Remarks	Oper and Insp Stamp	Date	Qty Comp	Qty Rej
60 (continued)				5 - INSTALL BELT/EVIL/E SPARK, ITEM 24 TO END WIRE 1780113, WITH CONCAVE SIDE UP. /INSTALL DINGS WHERE ITEM 14 & OUTER SUPPORT, ITEM 18 THEN SPACER, ITEM 10 & ENDURE STAIN STACE 'S'. ITEM 23.					
70	130			<u>BELLOWS SIZING</u> - MEASUREMENTS					
				a - BELLOWS MEASUREMENTS AS SHOWN ON SHEET BELOW. 'G' = 'H' =					
				b - MEASURE DIST. 'J' FROM TOP OF INNER GUN TO OUTSIDE BODY FLANGE. IF INNER GUN IS ABOVE THE BODY FLANGE, MEASURE DIST. NECESSARY, POSSIBLY 117-15 BODOWN. J = D - .609 (.01" AT 0.006 .60) SINCE .006 OK .100					
									
				ON ENCLASSED SHEET					
				REMOVED W/ SHEET					

MEG OPERATION ROUTING - OPERATION SEQUENCE SHEET

104

5716068-102

Oper No.	Dept No.	Setup	Run	MACHINE AND OPERATION DESCRIPTION	Tools, Gages and Remarks	Oper and Inop Stamp	Date	Qty Comp	Qty Rej
20 (Continued)	C.	Bellow's Setup 55. Item 22.							
		K' 15 AS FOLLOWS:							
		K = H - G - J							
80 630				BELLOW'S ASSEMBLY & ADJUSTMENT					
				A. DISASSEMBLE THE SPRING, NUT & NUT, ITEM 9 TO HOLDING ASSY, ITEM 2. TOADS NUT TO 50-100 INCH-LBS.					
				B. SCREEN BELLOW'S ASSY, ITEM 4B OR 49 TO CLEVIS, ITEM 15. ADJUST BELLOW'S ASSY AS SHOWN BOTTOMED ON THE MIDDLE CLEVIS, BACK OFF ONE FULL TURN PROVIDED THE ONE FULL TURN ADJUSTMENT TO SET THE CENTER LINE OF THE TENSION IN THE BELLOWS ASSY PERIODICALLY TO THE CENTER LINE OF THE CLEVIS BOLT.					
				C. POSITION SPRING ASSY, ITEM 45 POSITIONED IN OPB. 70 ON BELLOWS ASSY, CLAMPS SPRING, ITEM 10 & SPRING STACK, TENS 23 ON BELLOWS ASSY SUPPORT, ITEM 17.					

MFG OPERATION ROUTING - OPERATION SEQUENCE SHEET

SHEET 14 OF 22

Oper No.	Dept No.	Setup	Run	MACHINE AND OPERATION DESCRIPTION	Tools, Gages and Remarks	Oper and Insp Stamp	Date	Qty Comp	Qty Rej
80	(CONTINUED)	E	Carefully	Assess. Bushings ass'y over					
				BELLOWS ASSY ON TO THE BODY PLATE.					
				Be sure the housing does not hang					
				up on the body vice stand or					
				SHIM STOCK.					
				F. For ease of assembly bolts,					
				ITEM 7 & washers, ITEM 4 &					
				compress the housing to meet					
				body by using an Allen wrench.					
				TOECLIPS TO 100 - 140 INCH LBS.					
				G. Assess. next. ITEM 95, TO BELLOW'S					
				SHIMS & TOECLIPS TO 50 - 70 INCH LBS.					
				CONT'D - NEXT PAGE					

MFG OPERATION ROUTING - OPERATION SEQUENCE SHEET

Part No.

5716068-102

EER5716068

A-18

Oper No.	Dept No.	Setup	Run	MACHINE AND OPERATION DESCRIPTION	Tools, Gages and Remarks	Oper and Insp Stamp	Date	Qty Comp	Qty Rej
90 130				SHUT OFF VALVE					
				a. PROCESS DBS-10-030 BUSHING INTO ASSSEMBLED BUSHING & RETAINER & CAP ASSY. (USE PRESSURE PRESS-1E W/C)	680-0-905-1 MATERIAL: 7004				
				ASSEM. M524693C26 SCREWS & TORQUE TO 10-12 INCH/LB/S.					
				b. ASSEMBLE PISTON GUIDE 5716086, SEAL 1151-00-375, PISTON 5716085,005 SEAL, 1767195 GUIDE, FLW 5716099, NUT M521043-5. TORQUE NUT TO 200-220 INCH/LB/S.					
				INSTALL SUB-ASSSEMBLY INTO GUIDE BUSHING (REMOVING INSTALLED IN CAP ASSY) & VERIFY THAT PISTON WILL MOVE THRU IT'S COMPLETE STROKE WITHOUT METAL-TO-METAL CONTACT. REMOVE PISTON PIN 56025,					
				ASSEM. & INSTALL PISTON PIN 56025, ITEM 26. (NOTE: LIGHT PRESS F/T MAY BE REQUIRED TO INSTALL PISTON GUIDE INTO PISTON)					

MFG OPERATION ROUTING - OPERATION SEQUENCE SHEET

Part No.

571606B-102

EER5716068

A-19

Oper No.	Dept No.	Setup	Run	MACHINE AND OPERATION DESCRIPTION	Tools, Gages and Remarks	Oper and Insp Stamp	Date	Qty Comp	Qty Rej
90 (continued)				C- INSTALL SPONGE CC-0634-12. COMPRESS SCREWS ONTO PISTON & INSERT PISTON INTO CAP ASSEMBLY. ITEM 3. A VACUUM APPLIED TO THE POLE IN THE CAP ASSY WILL ASSIST IN INSERTING THE PISTON & INSTALLING THE ASSY onto the VALVE BODY.					
				D- INSERT SCREW. ITEM 37 TO BODY FLANGE. PRESS CAP ASSY TO BODY USING SCREW, ITEM 31 & WASHERS. ITEM 32. TORQUE TO 50-70 INCH LBS.					
100	130			E- TEST & CALIBRATION INSTALL METER & OUTLET TEST CABLES \$650-1799 USE 'O' RINGS 2-131 & 2-132 OR FOAM. (C.R. MS29513-131 OR 143)					
				F- LEAK TEST - SOURCE AS STATED ON MATERIALS SHEET 30. WITH OUTLET PORT UNBLOCKED, OPEN 3000 PSI OF GNE TO THE METER & SHUT OFF VALVE IMMEDIATELY. ALLOW PRESSURE 5 MINUTES. LEAKS REASSURED TO 2500.					


MFG OPERATION ROUTING - SKETCH SHEET

CONTROL NUMBER

5716068-102

Part No.

Oper No.	Dept No.	Setup	Run	MACHINE AND OPERATION DESCRIPTION	Tools, Gages and Remarks	Oper and Insp Stamp	Date	Qty Comp	Qty Rej
100 (cont'd)				Vent and off valves port. Cols OUTLET PORT TO MARY 500 ± 25 P/M TO INLET PORT TO 400 FOR 5 MINUTES. REDUCE PRESSURE TO 2500.					



MFG OPERATION ROUTING - OPERATION SEQUENCE SHEET

Part No.

SHEET 1 OF 2

CONTROL NUMBER

5716068-102

Oper No.	Dept No.	Setup Run	MACHINE AND OPERATION DESCRIPTION	Tools, Gages and Remarks	Oper and Insp Stamp	Date	Qty Comp	Qty Rej
100 (continued)	B		EXTERNAL LEAKAGE TESTS					
			SET UP AS SHOWN ON SKETCH SKETCH #3. WITH THE UNIT NOT VENTED. APPLY 200 PSIG TO THE UNIT & SHUT ONE PORTS SIMULTANEOUSLY. OBSERVE ANY INDICATION OF EXTERNAL LEAKAGE FROM PLUMBED SCAFFS.					
			MONITOR LEAKAGE FOR ONE MINUTE. LEAKS PRESSURE TO 2000. VENT THE SHUT OFF VALVE PORT. CAR THE CURRENT PORT & ADJUST 300 PSIG TO THE INLET. OBSERVE ANY INDICATION OF EXTERNAL LEAKAGE FROM PLUMBED SCAFFS. MONITOR LEAKAGE FOR ONE MINUTE MINIMUM. REACHES 300 PRESSURE TO 2000.					
			C- INTERNAL LEAKAGE TESTS					
			SET UP AS SHOWN IN SKETCH SKETCH #3 THE UNIT NEEDS NOT BE SUBJECTED TO VACUUM. MEASURE THE LEAKAGE FROM THE UNIT PORTS WITH THE UNIT PRESSED OUT VACUUM PORTS Pressed in 200 Vacum, 1500 & 2000 PSIG Gage.					

SHE - I
CONTROL NUMBER

MFG OPERATION ROUTING - OPERATION SEQUENCE SHEET

Part No.

5716068-102

100 (continued)

THE LEAKAGE SHOULD BE 10 SCIM
MAXIMUM. RECORDED BELOW.

~~400 25/16 =~~

= 3150000

MEASURE THE LENGTH AND THE
BUTTER OF THE COOKED MEAT
THE OUTLET PORT IS CAPPED &
TO 200 PSIG GL². THE LEAKAGE
MAY BE 200 SCFM MAXIMUM.

RECORDED BY JACKSON & CO. 1900 1916

MFG OPERATION ROUTING - SKETCH SHEET


Part No.

5716068-102

MACHINE AND OPERATION DESCRIPTION

Oper No.	Dept No.	Setup	Run	Tools, Gages and Remarks	Oper and Insp Stamp	Date	Qty Comp	Qty Req
100	(cont'd from pg)							

0.3000



LEAD ASSESS TEST SET UP

MFG OPERATION ROUTING - OPERATION SEQUENCE SHEET

Oper No.	Dept No.	Setup	Run	MACHINE AND OPERATION DESCRIPTION	Tools, Gages and Remarks	Oper and Insp Stamp	Date	Qty Comp	Qty Rej
100 (continued)	C. FLOW TEST - SET UP ASSUMED FOR HIGH FLOW TO ST.			<p><u>ROUNDTOPS</u></p> <p>INLET PRESSURE 0-2000 PSIG (2000psi) OUTLET PRESSURE 0-500 PSIG (500psi) DOWN STREAM ORIFICE 0.687 dia. INLET & OUTLET TEMP. 450 TO 200°F (200°C)</p> <p><u>Caution - DO NOT, AT ANY TIME,</u> <u>ALLOW THE DOWN STREAM PRESSURE</u> <u>TO EXCEED 450 PSIG</u></p> <p>INSTALL THE SOLENOID OPERATED SHUT OFF VALVE WITH THE N.O. PORTS CONNECTED TO THE SHUT OFF VALVE PORT & THE SUPPLY PORT CONNECTED TO THE INLET PORT. CONNECT THE SOLENOID PORT PORT TO THE OUTLET PORTS.</p> <p>OPEN THE SOLENOID VALVE OR ENTER 41260 OPEN 400 PSIG INLET PRESSURE.</p> <p>ENGAGE THE FORWARD VALVE, POSITION THE INLET PRESSURE TO 400 TO 450 PSIG</p>					

MFG OPERATION ROUTING - OPERATION SEQUENCE SHEET

卷之三

577/6 0668.102

Oper No.	Dept No.	Setup	Run	MACHINE AND OPERATION DESCRIPTION	Tools, Gages and Remarks	Oper and Insp Stamp	Date	Qty Comp	Qty Rej
100	continued								
				AND NOTE THE OUTLET PRESSURE. AT THE OUTLET PRESSURE 15 PSIG 300 & 375 PSIG, INCREASING INLET PRESSURE TO 1000 PSIG THEN REDUCE TO 250. OPERATE TERMINATE TEST.					
				EXAMINE THE OUTLET PRESSURE TRACE & DETERMINE THE OUTLET PRESSURE BAND. THE DESIRED 15 PSIG ± 2 PSIG. @ +25°F WITH 500 PSIG INLET PRESSURE LOSSLESS TUBE BLOWERS PER 1000 FT ACHIEVE THE DESIRED PRESSURE LEVEL. INCORPORATING STURM AND INCREASE THIS PRESSURE LEVELS. DO SWING CHANGES AND RESET IN 12 TO 16 PSI PRESSURE CHANGES.					
				AFTER FINAL SHIFT CHANGES MAKE BETWEEN MODES, REURN PUMP TO ST FROM 400 TO 2000 TO 400 PSIG.					

WFG OPERATION ROUTING - OPERATION SEQUENCE SHEET

Part No.

5776068-02


OPER. NO.	DEPT. NO.	SETUP	RUN	MACHINE AND OPERATION DESCRIPTION	TOOLS, GAGES AND REMARKS	OPER. AND INSP. STAMP	DATE	QTY COMP.	QTY REJ.
110	130			LOCKWELL 1000 HP 5716088					
120	130	TEST	125	5716187					
130	110	100%	100%	LOCKWELL 1000 HP 5716068 DEC 12 1987					
140	20			VALVE 100%					
				STOCK					


SYSTEMS DIVISION
PARKER HANNIFIN


NO.	EER5716068		BY	WT	PAGE	B-1
REV LTR	NC					
DATE	1-19-72					


APPENDIX B

BELLEVILLE SPRING FORCE - DEFLECTION CURVE









SYSTEMS DIVISION
PARKER HANNIFIN

NO.	EER5716068		BY	WT	PAGE	C-1
REV LTR	NC					
DATE	1-19-72					

APPENDIX C

CHARGED BELLOWS- FORCE DEFLECTION CURVE

716050
TS17501

100
LBS

FORCE


TOTAL RATE = 940 LB/IN


-.020 IN -


DEFLECTION

FORCE VS DEFLECTION OF HELIUM
CHARGED BELLOWS INSTALLED IN
HYDROGEN MFC, S/N 01

S/N TS17501







020/in
FORCE VS DEFLECTION OF
HELIUM CHARGED BELLOWS
INSTALLED IN OXYGEN MFC
S/N 02

EN TS 7503

C₂

SYSTEMS DIVISION
PARKER HANNIFIN

NO.	EER5716068		BY	WT	PAGE	D-1
REV LTR	NC					
DATE	1-19-72					

APPENDIX D

PTS 5716187

SYSTEMS DIVISION

PARKER HANNIFIN • 18321 JAMBOREE BOULEVARD • IRVINE, CALIFORNIA 92664

CONTROLLED DOCUMENT

NUMBER: PTS5716187

TITLE: Acceptance Test Procedure for
Mass Flow Controller Assy
PN 5716187

REFERENCE: 1. Parker Program S156
 2. NASA P.O. # NAS9-11750

PREPARED BY: W. Taylor
W. Taylor
Sr. Project Engr.

APPROVED BY: J. Ulanovsky
Mgr., Design Engr.

NO.	PTS5716187		BY	WT	PAGE	i
REV LTR	NC					
DATE	10-18-71					

LIST OF EFFECTIVE PAGES

This document consists of 6 pages as follows:

<u>Page</u>	<u>Rev Ltr</u>
Cover	NC
i and ii	NC
1 through 3	NC

NO.	PTS5716187	BY	WT	PAGE	II
REV LTR	NC				
DATE	10-18-71				

CONTENTS

<u>Section</u>		<u>Page</u>
1.0	SCOPE	1
2.0	TEST REQUIREMENTS	1
2.1	Test Facilities	1
2.2	Test Results	1
2.3	Environmental	1
2.4	Test Media	1
2.5	Tolerances	1
3.0	DETAILED TEST PROCEDURES	2
3.1	Solenoid Valve	2
3.2	5716154 Inlet Adapter Proof Test	3
3.3	5716155 Outlet Adapter Proof Test	3
3.4	5716068-101 and -102 Mass Flow Controller Assy.	3

NO	PTS5716187	BY	WT	PAGE	1
REV LTR	NC				
DATE	10-18-71				

1.0 SCOPE

This document specifies the test procedure for the Mass Flow Controller (MFC) Solenoid Pilot Valve and Adapters supplied to NASA Houston for controlling the flow of gaseous hydrogen and gaseous oxygen propellants, PN 5716187.

2.0 TEST REQUIREMENTS

2.1 Test Facilities - All testing shall be conducted at the Systems Division, Parker Hannifin Corporation, Irvine California Facility.

2.2 Test Results - Complete test results data shall be recorded for each acceptance test.

2.3 Environmental - Unless otherwise specified all testing shall be conducted within the following environmental conditions:

- a. Temperature: $75^{\circ} \pm 20^{\circ}\text{F}$
- b. Relative Humidity: 90 percent or less
- c. Barometric Pressure: Local Atmosphere

2.4 Test Media - The test media used for acceptance testing shall be nitrogen in accordance with MIL-P-27401.

2.5 Tolerances - Unless otherwise specified, the following tolerances apply to the application of test requirements and the recording of data:

- a. Temperature: $\pm 3^{\circ}\text{F}$
- b. Barometric Pressure: ± 5 percent
- c. Pressure: ± 1 percent
- d. Flow Rate: ± 2 percent
- e. Leakage Rate: ± 3 percent

NO.	17185716187		BY	WT	PAGE	2
REV. LIR	NC					
DATE	10-18-71					

3.0 DETAILED TEST PROCEDURES

3.1 Solenoid Valve

3.1.1 Proof Pressure

3.1.1.1 Setup - Connect pressure source to Ports A, B and C to permit pressurizing all three ports simultaneously.

3.1.1.2 Procedure - Apply 3000 psig for 5 minutes.

3.1.2 External Leakage

3.1.2.1 Setup - Same as proof pressure test.

3.1.2.2 Procedure - Apply 2000 psi to ports and immerse valve in freon or alcohol past the flange where solenoid mounts. Observe for bubbles. There shall be no bubbles during 2 - minute test.

3.1.3 Internal Leakage

3.1.3.1 Setup - Connect pressure source to NO Port A and connect tube to Port B. Cap Port C. Immerse tube in liquid.

3.1.3.2 Procedure - Apply 2000 psi to Port A and observe for bubbles. Record number of bubbles during 2 minute test.

Remove tube from liquid and energize valve with 28 volts DC. Immerse tube and observe for bubbles. Record number of bubbles during 2 minute test.

3.1.4 Actuation

3.1.4.1 Setup - Connect pressure source to NO Port A and connect gauge to Port C. Leave Port B open.

3.1.4.2 Procedure - Apply 2000 psi to Port A and energize solenoid with 28 volts DC. De-energize solenoid. Repeat 5 times observing gauge. Valve must open and close promptly as signified by pressure at the gauge.

NO.	PTS5716187	BY	WT	PAGE	3
REV LTR	NC				
DATE	10-18-71				

3.2 5716154 Inlet Adapter Proof Test

3.2.1 Setup - Install Inlet Adapter in Fixture No. S65-0-1802.

3.2.2 Procedure - Apply 3000 psi for 5 minutes.

3.3 5716155 Outlet Adapter Proof Test

3.3.1 Setup - Install Outlet Adapter in Fixture No. S65-0-1802.

3.3.2 Procedure - Apply 2000 psig for 5 minutes.

3.4 5716068-101 and -102 Mass Flow Controller Assy

Test per PTS5716068 Acceptance Test Procedure.

SYSTEMS DIVISION
PARKER HANNIFIN

NO.	EER5716068		BY	WT	PAGE	E-1
REV LTR	NC					
DATE	1-9-72					

APPENDIX E

PTS 5716068

SYSTEMS DIVISION

PARKER HANNIFIN • 18321 JAMBOREE BOULEVARD • IRVINE, CALIFORNIA 92664

CONTROLLED DOCUMENT

NUMBER: PTS5716068


TITLE: Acceptance Test Procedure for
Mass Flow Controller Assys;
PN's 5716068-101 and 5716068-102

RELEASE HISTORY


DATE	REVISION	E.O. NO.	MICROFILM	DATE	REVISION	E.O. NO.	MICROFILM
18-Oct-71	NC	01					


REFERENCE: 1. Parker Program S156
2. NASA P.O. # NAS9-11750

PREPARED BY:


W. Taylor
Sr. Project Engr.

APPROVED BY:


J. Ulanovsky
Mgr., Design Engr.



SYSTEMS DIVISION
PARKER HANNIFIN

NO	PTS5716068		BY	WT	PAGE	i
REV LTR	NC					
DATE	10-8-71					

LIST OF EFFECTIVE PAGES

This document consists of 9 pages as follows:

<u>Page</u>	<u>Rev Ltr</u>
Cover	NC
i and ii	NC
1 through 6	NC

NO	PTS5716068	BY	WT	PAGE	II
REV LTR	NC				
DATE	10-8-71				

CONTENTS

<u>Section</u>	<u>Page</u>
1.0 SCOPE	1
2.0 TEST REQUIREMENTS	1
2.1 Test Facilities	1
2.2 Test Results	1
2.3 Environmental	1
2.4 Test Media	1
2.5 Tolerances	1
2.6 Equipment	2
3.0 DETAILED TEST PROCEDURES	2
3.1 Proof Pressure and External Leakage	2
3.2 Internal Leakage	2
3.3 Response & Regulation	3
Figure 1	5
Figure 2	6

NO.	PTS5716068		WT	PAGE	1
REV LTR	NC				
DATE	10-8-71				

1.0 SCOPE

This document specifies the test procedure for the Mass Flow Controller (MFC) supplied to NASA Houston for controlling the flow of gaseous hydrogen and gaseous oxygen propellants,

PN 5716068-101 Hydrogen Mass Flow Controller
 5716068-102 Oxygen Mass Flow Controller

2.0 TEST REQUIREMENTS

2.1 Test Facilities - All testing shall be conducted at the Systems Division, Parker Hannifin Corporation, Irvine California Facility.

2.2 Test Results - Complete test results data shall be recorded for each acceptance test.

2.3 Environmental - Unless otherwise specified all testing shall be conducted within the following environmental conditions:

- a. Temperature: $75^{\circ} \pm 20^{\circ}\text{F}$
- b. Relative Humidity: 90 percent or less
- c. Barometric Pressure: Local Atmosphere

2.4 Test Media - The test media used for acceptance testing shall be nitrogen in accordance with MIL-P-27401.

2.5 Tolerances - Unless otherwise specified, the following tolerances apply to the application of test requirements and the recording of data:

- a. Temperature: $\pm 3^{\circ}\text{F}$
- b. Barometric Pressure: ± 5 percent
- c. Pressure: ± 1 percent
- d. Flow Rate: ± 2 percent
- e. Leakage Rate: ± 3 percent

NO	PTS5716068		BY	WT	PAGE	2
REV LTR	NC					
DATE	10-8-71					

2.6 Equipment (Shown on Figure 2)

B_1 , B_2 , B_3	Jamesbury 1" Ball Valve
D_1	Grove Model M-13958-D
D_2	Dome Loaded Pressure Regulator
G_1 , G_2 , G_3 , G_4	APCO 112900-23 Dome Loaded
G_5	Pressure Regulator
H_1	Pressure Gauge, psi
H_2	Differential Pressure Gauge,
Mixer	inches H_2O
Recorder	Marotta Hand Loader
S	Benbow Hand Loader
Venturi Flow Meter	Parker S65-0-1795
	7 Channel
	Victor Solenoid Valve
	SV 30A32P4T
	Barco BR 31615-68-61

3.0 DETAILED TEST PROCEDURES

3.1 Proof Pressure and External Leakage

3.1.1 Setup - The test setup shall be as shown in Figure 1.

3.1.2 Procedure

Inlet - Open shutoff valves V_1 and V_3 and close V_2 . Immerse unit and apply 3000 psig with regulator valve for two minutes. Reduce pressure to 2000 psig and observe for bubbles. There shall be no bubbles in a two minute test.

Outlet - Close shutoff valve V_1 and V_3 and open valve V_2 . Apply 525 psig to inlet port for two minutes. Reduce pressure to 400 psig and observe for bubbles. There shall be no bubbles in a two minute test.

3.2 Internal Leakage

3.2.1 Setup - Use setup shown in Figure 1 except attach flow meters to outlet of shutoff valves V_2 and V_3 suitable for measuring internal leakage.

NO	PTS5716068	BY	WT	PAGE	3
REV LTR	NC				
DATE	10-8-71				

3.2.2 Procedure

Poppet - Open shutoff valves V_1 and V_3 and close V_2 . Using regulator valve apply pressure to inlet port of 400, 1000 and 2000 psig. Record leakage from V_3 .

Piston Seal - Close shutoff valves V_1 and V_3 and open V_2 . Using regulator valve apply pressure to inlet port of 50, 100, 200 and 400 psig. Record leakage from V_2 .

3.3 Response & Regulation

3.3.1 Setup - Use setup shown in Figure 2. For tests conducted without adding LN_2 , use orifice diameter of .687 inch. For tests conducted with LN_2 use orifice diameter of .624 inch. Record p_1 , p_2 , p_3 , T_1 , T_2 , and voltage at solenoid.

3.3.2 Ambient Temperature Tests (.687 inch orifice)

3.3.2.1 Using dome loader D_1 , establish the pressure which results in 550 ± 50 psig at P_1 when the MFC is open and flowing. Open MFC shutoff poppet by closing switch. Use a recorder speed sufficient to obtain response of unit. Close MFC by opening switch.

3.3.2.2 Open MFC by closing switch with inlet pressure of 350 ± 50 psig. Increase inlet pressure to 1000 psig and lower to 350 psig, obtaining a trace of outlet pressure as inlet pressure varies.

3.3.2.3 Repeat 3.3.2.1 with inlet pressure set for 1000 ± 50 psig.

3.3.3 Cold Test (.624 inch orifice)

3.3.3.1 Using dome loader D_1 establish the pressure which results in 550 ± 50 psig when the MFC is open and with LN_2 injected in quantity sufficient to produce an outlet temperature of -210°F or lower. Using dome loader D_2 , establish a pressure on the LN_2 container required to flow LN_2 at the required rate when ball valve B_2 is opened.

NO	PTS5716068	BY	WT	PAGE	4
REV	NC				
DATE	10-8-71				

3.3.3.2 Close switch and open ball valve B_2 simultaneously. Obtain a trace of outlet pressure as the temperature drops to -210°F .

3.3.3.3 Close B_2 (and increase pressure of dome loader D_1 if required to maintain inlet pressure to MFC) and obtain trace of outlet pressure as temperature warms to ambient.

3.3.3.4 Repeat 3.3.3.1 - 3.3.3.3 with inlet pressure of 1000 ± 50 psig.

3.3.4 During response and regulation test

- a. Note any region of instability.
- b. Observe for evidence of external leakage when MFC is cold.




FIGURE 1




TABLE 2

SYSTEMS DIVISION
PARKER HANNIFIN

NO.	EER5716068		BY	WT	PAGE	F-1
REV LTR	NC					
DATE	1-9-72					

APPENDIX F

ACCEPTANCE TEST DATA SHEETS

NC WT 1-9-72

NC WT

1-9-72

RECEIVED BY 05H15Z 11 NOV 21

RECEIVED
MAY 21 1968

PROOF PRESSURE & EXTERNAL LGS.

ART NO. & NAME

MASS FLOW CONTROLLER

SAMPLE NO. TS15201

BAPOM.

5716068 - 101

TEST

EST. 1919

MEDIUM EN_2

SET BULB
TEMP. °F.

MEDIUM

DRY BULB

TEMP. °

TEMP. °F.

H₂ MFC S/N 01

H. _____
A-1B6 (4-69)

REF. SPEC.

DATA SHEET NO.

REV. LTR. NC BY WT DATE 1-9-72

DATA BY: OSHIRO DATE 11-12-71 APPR.

TEST:

INTERNAL LEAKAGE

PART NO. & NAME

5716068 - 101 MASS FLOW
CONTROLLER

SAMPLE NO.	T515201	SAROM. PRESS.	IN. HG
TEST MEDIUM	GN ₂	WET BULB TEMP.	°F
MEDIUM TEMP.	75 °F.	DRY BULB TEMP.	°F.

PTS 5716068 PARA NO.	INLET PRESSURE		OUTLET PRESSURE		TIME		LEAKAGE	
	REQ	ACTUAL	REQ	ACTUAL	REQ	ACTUAL	REQ	ACTUAL
	PSIG	PSIG	PSIG	PSIG	SEC	SEC	—	SCCM
3.2.2 POPPET LKG.	400	400	—	—	—	*	—	50
	1000	1000	—	—	—	*	—	330
	2000	2000	—	—	—	*	—	1375
PISTON SEAL LKG.	50	50	—	—	—	*	—	700
	100	100	—	—	—	*	—	900
	200	200	—	—	—	*	—	1180
	400	400	—	—	—	*	—	1890
*	USED	FLOWMETER RANGE	PARKER 5.0 TO 23,000	STOCK NO SCCM	3625 GN ₂			
SETUP PER	H ₂	MFC	S/N 01					

J. H. _____ REF. SPEC. _____ DATA SHEET NO. _____

REV. LTR. NC BY WT DATE 1-9-72

REVIEWED BY DATE

DATA BY: OSBIR 3 DATE 11-19-31 APPROVED

TEST:

PROOF PRESSURE & EXTERNAL LKS

ART NO. & NAME

5716068-101

MASS FLOW CONTROLLER

SAMPLE NO. T515202

BARON

TEST

SET BULB

100

TEST
MEDIUM GN_2

WET BULB
TEMP.

6

MEDIUM

DRY BULB

— 1 —

SETUP PER _____ **H₂ MFC** **S/N** **O₂**

J. H. _____ REF. SPEC. _____ DATA SHEET NO. _____

PHILA 1P6 (4-69)

REPORT NO. EER5716068 PAGE F-5
 REV. LTR. NC BY WT DATE 1-9-72
 DATA BY: 254120 DATE 11-19-71 APPR.

TEST: INTERNAL LEAKAGE

ART. NO. & NAME

MASS FLOW

5716068-101 CONTROLLER

SAMPLE NO. TS151CZ

BAROM.

PRESS.

IN. HG

TEST MEDIUM GN₂

WET BULB TEMP.

°F.

MEDIUM TEMP.

DRY BULB TEMP.

°F.

	INLET PRESSURE		OUTLET PRESSURE		TIME		LEAKAGE	
ART. NO.	REQ	ACTUAL	REQ	ACTUAL	REQ	ACTUAL	REQ	ACTUAL
PTSS716068	PSIG	PSIG	PSIG	PSIG	SEC	SEC	—	SCCM
3.2.2	400	400	—	—	—	*	—	34
POPPET LKG	1000	1000	—	—	—	*	—	420
	2000	2000	—	—	—	*	—	1520
PISTON SEAL LKG	50	50	—	—	—	*	—	260
	100	100	—	—	—	*	—	610
	200	200	—	—	—	*	—	900
	400	400	—	—	—	*	—	1300
<hr/>								
* FLOWMETER								
STOCK NO. 2625								
RANGE 5.0 T 24000 SCFM GN ₂								

SETUP PER H₂ MFC S/N 02

J. H.

REF. SPEC.

DATA SHEET NO.

REV. LTR. NC BY WT DATE 1-9-72

NC WT

1-9-72

1181

PROOF PRESSURE & EXTERNAL LKS

ART NO. & NAME

MASS FLOW CONTROLLER

SAMPLE NO. T518202

BAROM

5716068 - 102

五〇四

三

TEST

WET B

MEDIUM

TEMPI

MEDIUM

QBY 8

MEDIUM
TEMP.

TEM

SEARCHED

O₂ MFC S/N 02

J. H. _____
PLA 1E6 (4-69)

REF. SPEC.

DATA SHEET NO.

REV LTR NC BY WT DATE 1-9-72

DATA BY: 2241R0 DATE 11-22-71 APPS

TEST.

INTERNAL LEAKAGE

ART NO. & NAME

MASS FLOW

5716068 - 102 CONTROLLER

SAMPLE NO. TS18207

BAROM

17 π_0

TEST

17 π_0

TEST
MEDIUM

8

MEDIUM

—

Ch MFC Sp 02

- 1 -

-REF. SPEC.

DATA SHEET NO.

PARKER  HANNIFIN

REPORT NO. EER5716068 PAGE F-12
REV. LTR. NC WT DATE 1-9-72
DATA BY: OSHA DATE 11-24-71 APPR.

TEST: PROOF TEST	SAMPLE NO. 5127	BAROM. PRESS.
PART NO. & NAME 516154 INLFT ADAPTOR	TEST MEDIUM INL	WET BULB TEMP. °F
	MEDIUM TEMP. °F	DRY BULB TEMP. °F

PT 5716197

T031 N2 565-0-1802

SETUP PER.

1

-REF. SPEC.-


DATA SHEET NO.


SYSTEMS DIVISION
PARKER HANNIFIN


NO.	EER5716068		BY	WT	PAGE	G-1
REV LTR	NC					
DATE	1-9-72					

APPENDIX G

PRESSURE CONTROL VS. PROPELLANT TEMPERATURE







SYSTEMS DIVISION
PARKER HANNIFIN

NO.	EER5716068		BY	WT	PAGE	H-1
REV LTR	NC					
DATE	1-9-72					

APPENDIX H

DVT 5716068



SYSTEMS DIVISION

PARKER HANNIFIN • 18321 JAMBOREE BOULEVARD • IRVINE, CALIFORNIA 92664

CONTROLLED DOCUMENT

NUMBER: DVT5716068

TITLE: Design Verification Test Procedure
for Mass Flow Controller Assy:
PN's 5716068-101 and 5716068-102

REFERENCE: 1. Parker Program S156
 2. NASA P.O. # NAS9-11750

PREPARED BY

W. Taylor
Sr. Project Engr.

APPROVED BY:

J. Ulanovsky
Mgr., Design Engr.

SYSTEMS DIVISION
PARKER HANNIFIN

NO	DVT 5716068		BY	WT	PAGE	i
REV LTR	NC					
DATE	10-8-71					

LIST OF EFFECTIVE PAGES

This document consists of 5 pages as follows:

<u>Page</u>	<u>Rev Ltr</u>
Cover	NC
i and ii	NC
1 through 2	NC

NO.	DVT5716068	BY	WT	PAGE	ii
REV LTR	NC				
DATE	10-8-71				

CONTENTS.

<u>Section</u>	<u>Page</u>
1.0 SCOPE	1
2.0 TEST REQUIREMENTS	1
2.1 Test Facilities	1
2.2 Test Results	1
2.3 Environmental.	1
2.4 Test Media	1
2.5 Tolerances	1
3.0 DETAILED TEST PROCEDURES	1
3.1 Internal Leakage.	1
3.2 Response & Regulation	1
3.3 Pressure Drop	2
3.4 Endurance.	2

1.0 SCOPE

This document specifies the test procedure to be followed for design verification testing of two mass flow controller assemblies,

PN 5716068-101 Hydrogen Mass Flow Controller
5716068-102 Oxygen Mass Flow Controller

2.0 TEST REQUIREMENTS

2.1 Test Facilities - All testing shall be conducted at the Systems Division, Parker Hannifin Corporation, Irvine California Facility.

2.2 Test Results - Complete test results data shall be recorded for each design verification test.

2.3 Environmental - Unless otherwise specified, all testing shall be conducted within the following environmental conditions:

- a. Temperature: $75^{\circ} \pm 20^{\circ}\text{F}$
- b. Relative Humidity: 90 percent or less
- c. Barometric Pressure: Local Atmosphere

2.4 Test Media - The test media used for design verification testing shall be nitrogen in accordance with MIL-P-27401.

2.5 Tolerances - Unless otherwise specified, the following tolerances apply to the application of the test requirements and the recording of data.

- a. Temperature: $\pm 3^{\circ}\text{F}$
- b. Barometric Pressure: ± 5 percent
- c. Pressure: ± 1 percent
- d. Flow Rate: ± 2 percent
- e. Leakage Rate: ± 3 percent

3.0 DETAILED TEST PROCEDURES

3.1 Internal Leakage - Conduct internal leakage test per paragraph 3.2 of PTS5716068.

3.2 Response & Regulation - Conduct response and regulation test per paragraph 3.3 of PTS5716068.

NO	DVT 5716068		BY	WT	PAGE	Z
REV LTR	NC					
DATE	10-8-71					

3.3 Pressure Drop

3.3.1 Setup - Use setup shown in Figure 2 of PTS5716068. Use .718 dia orifice in outlet line.

3.3.2 Procedure - Using D₁, set inlet pressure of 300 psig. Close switch, initiating flow through MFC. Increase inlet pressure from 300 to 400 psig in 10 psi increments. Record inlet pressure, outlet pressure, outlet temperature, Δp at venturi flowmeter.

3.4 Endurance

3.4.1 Setup - Use setup shown in Figure 2 of PTS5716068. Install .160 dia orifice in outlet line.

3.4.2 Procedure - Using D₁, establish a pressure of 550 ± 50 psig at inlet of MFC. Cycle unit **10,000 times** by closing and opening switch. At conclusion of test perform ambient temperature tests and internal leakage test (paragraph 3.2 and 3.3.2 of PTS5716068).

SYSTEMS DIVISION
PARKER HANNIFIN

NO. <u>EER5716068</u>		BY <u>WT</u>	PAGE <u>J-1</u>
REV LTR	NC		
DATE	1-9-72		

APPENDIX J

DESIGN VERIFICATION TEST DATA SHEETS

REPORT NO. EER5716068 PAGE J-2
 REV. LTR. NC BY WT DATE 1-9-72
 DATA BY C.H.R. DATE 11-26-71 APPR.

TEST:

INTERNAL LEAKAGE (AFTER 10000 CYCLES)

PART NO. & NAME

5716068-101 MASS FLOW CONTROLLER

SAMPLE NO. T515201

BAROM. PRESS. 14.7

TEST MEDIUM GN₂

WET BULB TEMP. 52°

MEDIUM TEMP. 0°

DRY BULB TEMP. 52°

ITEM	INLET PRESSURE		OUTLET PRESSURE		TIME		LEAKAGE	
	REQ	ACTUAL	REQ	ACTUAL	REQ	ACTUAL	REQ	ACTUAL
PT5716068	PSIG	PSIG	PSIG	PSIG	SEC	SEC	—	SCCM
PARA NO.								
3.2.2	400	400	—	—	—	*	—	45
POPET LKG.	1000	1000	—	—	—	*	—	500
	2000	2000	—	—	—	*	—	1300
PISTON SEAL LKG.	50	50	—	—	—	*	—	3200
	100	100	—	—	—	*	—	7500
	200	200	—	—	—	*	—	12500
	400	400	—	—	—	*	—	20000
 * FLOW METER #3625 (RANGE 5.0 to 24000 SCFM)								

SETUP PER H₂ MFC S/N 01

J. H. REF. SPEC. DATA SHEET NO.

PRESSURE DROP (GN_2)

T NO. & NAME MASS FLOW
5716068-181 CONTROLLER

SAMPLE NO.	TS15201	BAROM. PRESS.	14. MG
TEST MEDIUM	GN ₂	WET BULB TEMP.	°F.
MEDIUM TEMP.	°F.	DRY BULB TEMP.	°F.

H₂ MFC S/N 01

CHP PER

REF. SPEC.

DATA SHEET No.